



Unitary Products Group
5005 York Drive
Norman, OK 73069
1/877-874-7378

TECHNICAL SERVICE

Date: May 23, 2007

YS-028-07

To: All York Distributors
All York Branches
All Field Service Supervisors

Subject: New YorkGuard VI Control Board Kits for E4TS, E2FH, B2CH, & B1PS Heat Pumps & H4TS, H4TC, A/C Units

Wichita Engineering has recently completed the design of five replacement kits intended to supersede the present controls used on the subject product. Listed below are the new kits part numbers, where they are used, and what they replace.

1. Kit P/N S1-37323867001- New kit used to convert YorkGuard V control to YorkGuard VI control for E*FH applications. When current Source 1 inventory has been depleted, this kit will supersede YorkGuard V control p/n 18392 / 031-1957-000, 18383 / 031-01298-000, & S1-03101957000 defrost controls used on E*FH heat pumps.
2. Kit P/N S1-37323870001 – New kit, allows YorkGuard VI control to replace original YorkGuard IV control p/n S1-37323870001, used on B1PS, B2CH, E2FH, and other heat pumps.
3. Kit P/N S1-37323868001 – New kit used to convert YorkGuard V, TS interface control, & TS control to YorkGuard VI control for E4TS heat pump applications. When current Source 1 inventory has been depleted, this kit will supersede p/n 18387 / 031-01927-000, & S1-03101927000 TS interface controls, p/n 18386 / 031-01913-000, & S1-03101913000 TS controls & YorkGuard V modules shown in item # 1, used on E4TS heat pumps.
4. Kit P/N S1-37323869001- New kit used to convert H4TS A/C unit controls to YorkGuard VI control. When current Source 1 inventory has been depleted, this kit will supersede control p/n 18386 / 031-01913-000, & S1-03101913000 TS controls, and kit S1-37323590500 used on H4TS A/C units.
5. Kit P/N S1-37323866001 – New kit used to convert from TS single contactor control, p/n 18386 / 031-01913-000, & S1-03101913000, to electromechanical components on H1TC A/C units.

This new kits should start to arrive in Source 1 inventory by early June, 2007. Also, attached are copies of each kit instruction for your review.

Regards,

Robert Napp
Unitary Products Field Service
Johnson Controls

Greg Harrod
Unitary Products Controls Engineering Manager
Johnson Controls