



Heating and Air Conditioning


TECHNICAL GUIDE

SINGLE PACKAGE GAS/ELECTRIC UNITS AND SINGLE PACKAGE AIR CONDITIONERS

DH 036, 048 & 060

3, 4 & 5 NOMINAL TONS

12.2 THROUGH 13.2 SEER



DESCRIPTION

YORK Sunline Ultra® units are convertible single package air conditioners with a common cabinet and a common roof curb for the 3, 4 and 5 ton sizes. The units were designed for light commercial and commercial applications. They can easily be installed on a roof curb, slab, roof jack or frame.

All units include:

- Powder Paint finish that meets ASTM-B-117 750 hour salt spray standards
- Permanently lubricated motors
- Bottom or side air discharge configuration capability (field convertible)
- Manufactured under the quality standards of ISO9001
- Simplicity® Control Board
- Copper tube/aluminum fin coils
- Easy access to all components
- Rigging holes in base rails for lifting
- Fork lift slots on three sides
- Single point power connection
- Direct Drive or Belt Drive Blower with high static drive option
- Complete factory package - tested, charged and wired
- CSA agency listing on all units

WARRANTY

- Factory Limited Parts Warranty
- One-year parts warranty
- A Five-year parts warranty on the compressor and electric heat elements.
- Ten-year parts warranty on the gas-fired heat exchangers.



TABLE OF CONTENTS

DESCRIPTION	1	<u>Tbl. #</u>	<u>Pg. #</u>
PRODUCT NOMENCLATURE	3	10 SUPPLY AIR BLOWER PERFORMANCE (DH048 BELT DRIVE) - SIDE DUCT APPLICATION	12
FEATURES	4	11 SUPPLY AIR BLOWER PERFORMANCE (DH048 BELT DRIVE) - BOTTOM DUCT APPLICATION	13
FACTORY-INSTALLED OPTIONS	6	12 SUPPLY AIR BLOWER PERFORMANCE (DH060 BELT DRIVE) - SIDE DUCT APPLICATION	13
FIELD-INSTALLED ACCESSORIES	7	13 SUPPLY AIR BLOWER PERFORMANCE (DH060 BELT DRIVE) - BOTTOM DUCT APPLICATION	13
GUIDE SPECIFICATIONS	32	14 SUPPLY AIR BLOWER PERFORMANCE (3-5 TON) SIDE DUCT APPLICATION	14

LIST OF FIGURES


<u>Fig. #</u>	<u>Pg. #</u>	<u>Tbl. #</u>	<u>Pg. #</u>
1 UNIT CUTAWAY	5	15 SUPPLY AIR BLOWER PERFORMANCE (3-5 TON) BOTTOM DUCT APPLICATION	14
2 TYPICAL FIELD POWER & CONTROL WIRING	25	16 BELT DRIVE RPM SELECTION	15
3 UNIT DIMENSIONS (3 - 5 TON COOLING ONLY/ ELECTRIC HEAT) FRONT VIEW	26	17 BELT DRIVE BLOWER MOTOR AND DRIVE DATA	15
4 UNIT DIMENSIONS (3 - 5 TON COOLING/GAS HEAT) FRONT VIEW	26	18 STATIC RESISTANCES	15
5 UNIT WITH ECONOMIZER RAINHOOD	27	19 ELECTRIC HEATER CFM LIMITATIONS	17
6 UNIT WITH FIXED OUTDOOR AIR/MOTORIZED DAMPER RAINHOOD	27	20 ELECTRICAL DATA - DH036, 048 & 060 DIRECT DRIVE W/O POWERED CONVENIENCE OUTLET	18
7 UNIT DIMENSIONS (REAR VIEW)	28	21 ELECTRICAL DATA - DH036-060 BELT DRIVE W/O POWERED CONVENIENCE OUTLET	19
8 DISCONNECT/BLOWER ACCESS LOCATION	28	22 ELECTRICAL DATA - DH036-060 BELT DRIVE HIGH STATIC W/O POWERED CONVENIENCE OUTLET	20
9 TYPICAL APPLICATIONS	29	23 ELECTRICAL DATA - DH036, 048 & 060 DIRECT DRIVE W/POWERED CONVENIENCE OUTLET	21
10 FOUR AND SIX POINT LOADING	30	24 ELECTRICAL DATA - DH036-060 BELT DRIVE W/POWERED CONVENIENCE OUTLET	22
11 ROOF CURB DIMENSIONS	31	25 ELECTRICAL DATA - DH036-060 BELT DRIVE HIGH STATIC W/POWERED CONVENIENCE OUTLET	23

LIST OF TABLES

<u>Tbl. #</u>	<u>Pg. #</u>
1 SOUND POWER RATING	8
2 CAPACITY RATINGS - (ARI 210/240)	8
3 GAS HEAT RATINGS	8
4 2 STAGE GAS HEAT RATINGS	8
5 DH036 COOLING CAPACITIES (3 TON)	9
6 DH048 COOLING CAPACITIES (4 TON)	10
7 DH060 COOLING CAPACITIES (5 TON)	11
8 SUPPLY AIR BLOWER PERFORMANCE (DH036 BELT DRIVE) - SIDE DUCT APPLICATION	12
9 SUPPLY AIR BLOWER PERFORMANCE (DH036 BELT DRIVE) - BOTTOM DUCT APPLICATION	12

PRODUCT NOMENCLATURE

3-5 Ton Sunline Ultra Model Number Nomenclature



FEATURES

All models are available with a wide variety of factory-mounted options such as stainless steel heat exchangers, electric heaters, phase monitor, convenience outlet, dirty filter switch, disconnect switch, smoke detectors, and coil guard to make them suitable for almost every application.

All units are self-contained and assembled on full perimeter base rails with forklift holes on three sides and holes for overhead rigging. Every unit is completely piped, wired, charged and tested at the factory to simplify the field installation and to provide years of dependable operation.

All models (including those with an economizer) are suitable for either bottom or horizontal duct connections. For bottom duct, remove the sheet metal panels from the supply and return air openings through the base of the unit. For horizontal duct, remove the supply and return air panels on the rear of the unit.

All models are available with these “factory mounted” outdoor air damper options:

- Single enthalpy economizer
- Motorized outdoor air damper

Supply air blowers are equipped with either direct drive or belt drive that can be adjusted to meet the exact requirements of the job.

All compressors are equipped with internal pressure relief. Every refrigerant circuit includes a liquid line filter-drier, a high pressure switch and a suction line with a freeze-stat and low pressure/loss of charge switch to protect all system components.

- **Simplicity® Controls - Simplicity®** control boards have standardized a number of features previously available only as options or by utilizing additional controls.
 - **Low Ambient** - An integrated low-ambient control allows all units to operate in the cooling mode down to 0°F outdoor ambient without additional assistance. Optionally, the control board can be programmed to lockout the compressors when the outdoor air temperature is low or when free cooling is available.
 - **Anti-Short Cycle Protection** - To aid compressor life, an anti-short cycle delay is incorporated into the standard controls. Compressor reliability is further ensured by programmable minimum run times. For testing, the anti short cycle delay can be temporarily overridden with the push of a button.
 - **Fan Delays** - Fan on and fan off delays are fully programmable and are independent of one another. All units are programmed with default values based upon their configuration of cooling and heat.

- **Safety Monitoring** - The control board monitors the high and low-pressure switches, the freeze-stats, the gas valve, if applicable, and the temperature limit switch on gas heat units. The unit control board will alarm on ignition failures, compressor lockouts and repeated limit switch trips.
- **Nuisance Trip Protection** - To prevent nuisance trouble calls, the control board uses a “three strikes, you’re out” philosophy. The high and low-pressure switches and the freeze-stats must trip three times within two hours before the unit control board will lock out the compressor.
- **On Board Diagnostics** - Each alarm will energize a trouble light on the thermostat, if so equipped, and flash an alarm code on the control board LED. Each high and low-pressure switch alarm as well as each freeze-stat alarm has its own flash code. The control board saves the five most recent alarms in memory, and these alarms can be reviewed at any time. Alarms and programmed values are retained through the loss of power.

All units have long lasting powder paint cabinets with 750 hour salt spray test approval under ASTM-B117 procedures.

All models are CSA listed.


- **Warranty** - All models include a one-year limited parts warranty on the complete unit. Compressors and electric heater elements carry a five-year warranty. Gas heat exchangers carry a 10-year parts warranty.
- **Gas Heat Operation** - All single phase models with gas heat have minimum annual fuel utilization efficiency (AFUE) of 80%. All three phase models with gas heat have minimum steady state efficiency of 80%. Each section includes a durable heat exchanger with aluminized steel or optional stainless steel tubes, a redundant gas valve, spark ignition, power venting, an ignition module for 100% shut-off and all of the safety controls required to meet the latest ANSI standards.

The gas supply piping can be routed into the heating compartment through a hole in the base pan of the unit or through a knockout in the piping panel on the front of the unit.

- **Electric Heat Operation** - All electric heat models are wired for a single power source and include a bank of nickel chromium elements mounted at the discharge of the supply air blower to provide a high velocity and uniform distribution of air across the heating elements. Every element is fully protected against excessive temperature by thermal limit switches.

The power supply wiring can be routed into the control box through a threaded pipe connection (field supplied) in the base pan of the unit or through a knockout in the wiring panel on the side of the unit.

Gas/Electric



Electric/Electric and Heat Pump




FIGURE 1 - UNIT CUTAWAY

- **BAS Controls** - York's Sunline™ series units offer factory mounted BAS controls such as Simplicity® INTELLI-Comfort™, Novar, Honeywell, Johnson, and CPC.

FACTORY-INSTALLED OPTIONS

- **SINGLE INPUT ELECTRONIC ENTHALPY ECONOMIZERS** - Includes a slide-in / plug-in damper assembly with fully modulating spring-return motor actuator capable of introducing up to 100% outdoor air with nominal 1% leakage type dampers.

The enthalpy system contains one sensor that monitors the outdoor air and determines when the air is cool enough and dry enough to provide free cooling.

The rainhood is painted to match the basic unit and must be field-assembled before installing.

- **MOTORIZED OUTDOOR AIR INTAKE DAMPER** - Includes a slide-in / plug-in damper assembly with a 2-position, spring return motor actuator which opens to a pre-set position whenever the supply air blower is operating and will drive fully closed when the blower unit shuts down.

The rain hood is painted to match the basic unit and must be field assembled before installing.
- **PHENOLIC COATED EVAPORATOR AND CONDENSER COILS** - Special coating process that utilizes Technicoat 10-1™ processes. Coating is applied by total immersion of the complete coil for maximum protection.
- **ELECTRIC HEATERS** - Wired for single point power supply. These nickel chromium heater elements are provided with limit and automatic reset capability to prevent operation at excessive temperatures.
- **FILTER OPTIONS** - Standard units are shipped with 1" throw-away filters installed. 2" pleated filters are offered as a factory installed option.
- **CONVENIENCE OUTLET** - This 110 volt outlet can be "powered" by the unit with a stepdown transformer or the unit may be ordered with a "non-powered" convenience outlet that can be wired in the field.
- **DISCONNECT SWITCH** - For gas heat units and cooling units with electric heat, a HACR breaker sized to the unit is provided. For cooling only units, a switch sized to the largest electric heat available for the particular unit is provided. Factory installed option only.
- **BAS - Building Automation System Controls**
Simplicity® INTELLI-Comfort™ CONTROL - The York® Simplicity® INTELLI-Comfort™ control is factory installed. It includes a supply air sensor, a return air sensor, and an

outside air sensor. There are provisions for a field installed dirty filter indicator switch, an air-proving switch, an Outside Air Humidity sensor, a Return Air Humidity sensor, an Inside IAQ sensor, and an Outside Air IAQ sensor. Construction mode operation, 365-day real time clock with 7 day programming plus holiday scheduling is built-in. Two different modes of demand ventilation are achieved through the INTELLI-Comfort™ using CO₂ sensors. It uses an inside CO₂ sensor to perform Demand Ventilation. It can also use an Outside CO₂ sensor to perform Differential Demand Ventilation. It uses a Patented Comfort Ventilation algorithm to provide comfortable ventilation air temperature. The patented economizer-loading algorithm will protect the equipment when harsh operating conditions exist. Humidity in the occupied space or return duct can be monitored and controlled via humidity sensors and the on-board connection for hot gas re-heat system. It uses the INTELLI-Start™ algorithm to maximize energy savings by recovering the building from the Unoccupied Setpoints to the Occupied Setpoints just in time for the Occupied Time Period to begin. The Simplicity® INTELLI-Comfort™ balances space temperature, ventilation air temperature, CO₂ and humidity for ultimate comfort.

- **Simplicity® INTELLI-Comfort™ with MOD LINK CONTROL** - The York® Simplicity® INTELLI-Comfort™ with Mod Link control is factory installed. It includes all the features of the INTELLI-Comfort™ control with an additional control to translate communications from MOD-BUS to the BACnet MSTP protocol.
- **Novar® BAS CONTROL** - The Novar® ETC-3 building automation system controller is factory installed. Includes supply air sensor, return air sensor, dirty filter indicator switch, and air proving switch.
- **JOHNSON CONTROLS BAS CONTROL** - The Johnson Control YK-UNT-1126 building automation system controller is factory installed. Includes supply air sensor, return air sensor, dirty filter indicator switch, and air proving switch.
- **CPC BAS CONTROL** - The Computer Process Controls Model 810-3060 ARTC Advanced Rooftop building automation system controller is factory installed. Includes supply air sensor, return air sensor, dirty filter indicator switch and air proving switch.
- **HONEYWELL BAS CONTROL** - The Honeywell W7750C building automation system controller is factory installed. Includes air supply sensor, return air sensor, dirty filter indicator switch, and air proving switch.
- **SMOKE DETECTORS** - (supply air & return air) The smoke detectors stop operation of the unit by interrupting power to the control board if smoke is detected within the air compartment.

⚠ WARNING

Factory installed Smoke Detectors in the return air, may be subjected to freezing temperatures during “off” times due to outside air infiltration. These smoke detectors have an operational limit of 32°F to 131°F. Smoke detectors installed in areas that could be outside those limitations will have to be moved to prevent having false alarms.

- **COIL GUARD** - Customers can purchase a coil guard kit to protect the condenser coil from damage. This is not a hail guard kit.
- **STAINLESS STEEL HEAT EXCHANGER** - For applications in corrosive environments, this option provides a full stainless steel heat exchanger assembly.
- **STAINLESS STEEL DRAIN PAN** - An optional rust-proof stainless steel drain pan is available to provide years of trouble-free operation in corrosive environments.
- **BOTTOM DRAIN CONNECTION** - An optional bottom drain connection is available for inside the curb connections for applications in cold environments to reduce freezing drain lines.
- **PHASE MONITORS** - Designed to prevent unit damage. The phase monitor will shut the unit down in an out-of-phase condition.
- **DIRTY FILTER SWITCH** - This kit includes a differential pressure switch that energizes the fault light on the unit thermostat, indicating that there is an abnormally high pressure drop across the filters. Factory installed option or field installed accessory.
- **HINGED FILTER DOOR/“TOOLLESS” BLOWER AND ACCESS PANELS** (not hinged) - This option allows for easy access and maintenance.

NOTE: Knobs are shipped inside the unit to prevent shipping damage. These must be field installed for tool-less operation.
- **HIGH STATIC DRIVE OPTION** - May include a belt, blower pulley, motor pulley or a motor change to enhance blower performance.

FIELD-INSTALLED ACCESSORIES

- **SINGLE INPUT ELECTRONIC ENTHALPY ECONOMIZERS** - Includes a slide-in / plug-in damper assembly with fully modulating spring-return motor actuator capable of introducing up to 100% outdoor air with nominal 1% leakage type dampers.

The enthalpy system contains one sensor that monitors the outdoor air and determines when the air is cool enough and dry enough to provide free cooling.

The rainhood is painted to match the basic unit and must be field-assembled before installing.

- **MOTORIZED OUTDOOR AIR INTAKE DAMPER** - Includes a slide-in / plug-in damper assembly with a 2-position, spring return motor actuator which opens to some pre-set position whenever the supply air blower is operating and will drive fully closed when the blower unit shuts down.

The rain hood is painted to match the basic unit and must be field assembled before installing.

- **ELECTRIC HEATERS** wired for single point power supply. These nickel chromium heater elements are provided with limit and automatic reset capability to prevent operation at excessive temperatures.
- **ROOF CURBS** - Eight and fourteen-inch high roof curbs provide a water-tight seal between the unit and the finished roof. These full perimeter curbs meet the requirements of the National Roofing Contractors Association (NRCA) and are shipped knocked-down for field assembly.

Roof curbs are designed to fit inside the base rails of the unit and include both a wood nailing strip and duct hanger supports.

- **HIGH ALTITUDE NATURAL GAS** - Burner orifices and pilot orifices are provided for proper furnace operation at altitudes up to 6,000 feet.
- **PROPANE** - Burner orifices, pilot orifices and gas valve parts are provided to convert a natural gas furnace to propane.
- **HIGH ALTITUDE PROPANE** - Burner orifices and pilot orifices are provided for proper furnace operation at altitudes up to 6,000 feet. This accessory supplements the basic propane conversion kit.
- **LOW NOX KIT** - Required to reduce the emission of nitrogen oxides below 40 nano grams per joule.
- **POWER EXHAUST** - Our single input economizer options are available with power exhaust. Whenever the outdoor air intake dampers are opened for free cooling, the exhaust fan will be energized to prevent the conditioned space from being over-pressurized during economizer operation.

The power exhaust option can only be used on bottom duct configurations.

- **BAROMETRIC RELIEF DAMPER** - This damper accessory can be used to relieve internal building air pressure on units with an economizer without power exhaust. This accessory includes a rain hood, a bird screen and a fully assembled damper. With bottom duct connections, the damper should be mounted over the opening in the return air panel. With horizontal ductwork, the accessory should be mounted on the return air duct.

- **ENTHALPY ACCESSORY CONTROL KIT** - This kit contains the required components to convert a single enthalpy economizer to dual enthalpy.
- **BURGLAR BARS** - Mount in the supply and return openings to prevent entry into the duct work.
- **FLUE EXHAUST EXTENSION KIT** - In locations with wind or weather conditions which may interfere with proper exhausting of furnace combustion products, this kit can be installed to prevent the flue exhaust from entering nearby fresh air intakes.
- **CO₂ SENSOR** - Senses CO₂ levels and automatically overrides the economizer when levels rise above the present limits.
- **COIL GUARD** - Customers can purchase a coil guard kit to protect the condenser coil from damage. This is not a hail guard kit.
- **HAIL GUARD** - Hail Guard kit is available to prevent unit from hail damage. This is a sloped hood that fits above the coil.
- **GAS PIPING KIT** - This kit supplies all necessary fittings and shut off valve.

TABLE 1: SOUND POWER RATING¹

UNIT SIZE	CFM	ESP	BLOWER		SOUND POWER (db 10 ⁻¹² Watts)									
					Octave Band Centerline Frequency (Hz)								SWL dB(A)	dB(A) @ 10Ft. ²
					63	125	250	500	1,000	2,000	4,000	8,000		
036	1,200	0.6	LOW	0.60	84	84	74	67	69	62	57	52	74	41
048	1,600	0.55	HIGH	0.80	85	85	75	68	70	63	58	53	75	42
060	2,000	0.45	HIGH	1.00	86	86	76	69	71	64	59	54	76	43

1. These values have been accessed using a model of sound propagation from a point source into the hemispheric/free field. The dBA values provided are to be used for reference only. Calculation of dBA values cover matters of system design and the fan manufacture has no way of knowing the details of each system. This constitutes an expectation to any specification or guarantee requiring a dBA value or sound data in any other form than sound power level ratings.
2. At a distance of 10 feet from the blower.

TABLE 2: CAPACITY RATINGS - (ARI 210/240)¹

MODEL	MBH	EER ²	SEER ³
DH036	42.5	11.1	12.25
DH048	46.5	11.4	13.20
DH060	57.0	10.6	12.20

1. 80/67°F Indoor and 95°F outdoor.
2. EER = Energy Efficiency Ratio at full load - the cooling capacity in Btu's per hour (Btuh) divided by the power input in watts, expressed in Btuh per watt (Btuh/watt).
3. SEER = Seasonal Energy Efficiency Ratio.

TABLE 3: GAS HEAT RATINGS¹

MODEL	MBH INPUT	MBH OUTPUT	AFUE (%)	TEMP RISE °F
DH036N04	50	40	80.9	15 - 45
DH036N08	100	80	80.5	45 - 75
DH048N06	75	60	80.9	25 - 70
DH048N10	125	100	80.3	45 - 75
DH060N08	100	80	80.5	25 - 55
DH060N10	125	100	80.3	35 - 75

1. All units are single-stage heating.

TABLE 4: 2 STAGE GAS HEAT RATINGS

MODEL ¹	MBH INPUT		MBH OUTPUT		STEADY STATE EFFICIENCY		RISE		MINIMUM HEATING AIRFLOW (CFM)
	1 ST STAGE	2 ND STAGE	1 ST STAGE	2 ND STAGE	1 ST STAGE	2 ND STAGE	MIN.	MAX.	
DH036D06	45	75	35.8	60.8	79.4	81.1	35	70	790
DH036D10	69	115	55.2	92	80.0	80.2	55	90	950
DH048D06	45	75	35.7	60.8	79.4	81.1	25	70	790
DH048D10	75	125	60.4	100.6	80.5	80.5	45	75	1230
DH060D06	45	75	35.8	60.8	79.4	81.1	20	55	1010
DH060D10	75	125	60.4	100.6	80.5	80.5	35	75	1230

1. Models are 3Ø only.

TABLE 5: DH036 COOLING CAPACITIES (3 TON)

AIR ON EVAPORATOR COIL		TEMPERATURE OF AIR ON CONDENSER COIL																	
		85°F									95°F								
		TOTAL CAP. ¹ MBH	POWER INPUT ² kW	SENSIBLE CAPACITY ¹							TOTAL CAP. ¹ MBH	POWER INPUT ² kW	SENSIBLE CAPACITY ¹						
				ENTERING DRY BULB, °F									ENTERING DRY BULB, °F						
CFM	WB °F			86	83	80	77	74	71	68			86	83	80	77	74	71	68
1500	72	55.2	3.18	35.2	30.7	26.2	21.8	17.3	-	-	51.5	3.44	34.1	29.7	25.2	20.7	16.2	-	-
	67	49.1	3.13	41.7	37.2	32.8	28.3	23.8	19.4	14.9	45.8	3.35	40.2	35.7	31.3	26.8	22.3	17.8	13.4
	62	44.7	3.05	44.7	43.6	39.1	34.6	30.1	25.7	21.2	41.2	3.30	41.2	41.2	38.8	34.3	29.8	25.3	20.9
	57	42.4	3.05	42.4	42.4	42.4	37.9	33.4	29.0	24.5	39.9	3.35	39.9	39.9	39.9	35.4	31.0	26.5	22.0
1350	72	55.2	3.18	35.2	30.7	26.2	21.8	17.3	-	-	50.0	3.41	31.5	27.5	23.6	19.6	15.6	-	-
	67	49.1	3.13	41.7	37.2	32.8	28.3	23.8	19.4	14.9	44.5	3.32	37.2	33.2	29.2	25.3	21.3	17.3	13.3
	62	44.7	3.05	44.7	43.6	39.1	34.6	30.1	25.7	21.2	40.0	3.27	40.0	39.2	36.3	32.3	28.3	24.3	20.3
	57	42.4	3.05	42.4	42.4	42.4	37.9	33.4	29.0	24.5	38.8	3.32	38.8	38.8	37.5	33.5	29.6	25.6	21.6
1200	72	51.9	3.15	30.0	26.5	23.0	19.5	-	16.0	-	48.6	3.38	28.9	25.4	21.9	18.4	14.9	-	-
	67	46.1	3.10	35.7	32.2	28.7	25.2	21.7	18.2	14.7	43.2	3.29	34.2	30.7	27.2	23.7	20.2	16.7	13.2
	62	42.0	3.02	41.2	37.7	34.2	30.7	27.2	23.7	20.2	38.9	3.23	38.9	37.2	33.7	30.2	26.7	23.2	19.8
	57	39.8	3.03	39.8	39.8	37.3	33.8	30.3	26.8	23.3	37.6	3.29	37.6	37.6	35.1	31.6	28.1	24.6	21.1
1050	72	49.4	3.12	27.3	24.3	21.2	18.2	-	15.2	-	46.4	3.36	26.2	23.2	20.2	17.2	14.1	-	-
	67	43.9	3.07	32.6	29.6	26.5	23.5	20.5	17.4	14.4	41.2	3.27	31.1	28.1	25.0	22.0	19.0	16.0	12.9
	62	40.0	2.99	37.7	34.7	31.6	28.6	25.6	22.5	19.5	37.1	3.21	36.2	34.1	31.1	28.0	25.0	22.0	18.9
	57	37.9	3.00	37.9	37.0	34.5	31.4	28.4	25.4	22.3	35.9	3.27	35.9	34.9	32.3	29.3	26.3	23.2	20.2
900	72	46.9	3.09	24.6	22.1	19.5	16.9	14.4	-	-	44.2	3.34	23.6	21.0	18.4	15.9	13.3	-	-
	67	41.7	3.04	29.5	26.9	24.4	21.8	19.2	16.7	14.1	39.3	3.25	28.0	25.4	22.9	20.3	17.7	15.2	12.6
	62	38.0	2.96	34.2	31.6	29.1	26.5	23.9	21.4	18.8	35.4	3.20	33.5	30.9	28.4	25.8	23.2	20.7	18.1
	57	36.0	2.97	36.0	34.2	31.7	29.1	26.5	24.0	21.4	34.2	3.25	34.2	32.1	29.5	27.0	24.4	21.8	19.3

AIR ON EVAPORATOR COIL		TEMPERATURE OF AIR ON CONDENSER COIL																	
		105°F									115°F								
		TOTAL CAP. ¹ MBH	POWER INPUT ² kW	SENSIBLE CAPACITY ¹							TOTAL CAP. ¹ MBH	POWER INPUT ² kW	SENSIBLE CAPACITY ¹						
				ENTERING DRY BULB, °F									ENTERING DRY BULB, °F						
CFM	WB °F			86	83	80	77	74	71	68			86	83	80	77	74	71	68
1500	72	47.6	3.65	32.3	27.8	23.3	18.9	14.4	-	-	43.6	3.85	30.4	26.0	21.5	17.0	12.5	-	-
	67	42.5	3.56	39.0	34.5	30.0	25.6	21.1	16.6	12.1	39.3	3.76	37.8	33.3	28.8	24.3	19.9	15.4	10.9
	62	38.0	3.49	38.0	38.0	36.6	32.1	27.6	23.1	18.7	34.8	3.67	34.8	34.8	34.4	29.9	25.4	20.9	16.5
	57	37.4	3.54	37.4	37.4	37.4	32.9	28.5	24.0	19.5	34.9	3.73	34.9	34.9	34.9	30.5	26.0	21.5	17.0
1350	72	46.5	3.62	29.7	25.8	21.8	17.8	13.8	-	-	42.9	3.83	28.0	24.0	20.0	16.0	12.0	-	-
	67	41.6	3.53	36.0	32.0	28.0	24.0	20.1	16.1	12.1	38.6	3.74	34.8	30.8	26.8	22.8	18.8	14.9	10.9
	62	37.1	3.46	37.1	36.6	34.1	30.1	26.1	22.2	18.2	34.2	3.66	34.2	34.0	32.0	28.0	24.0	20.0	16.0
	57	36.5	3.52	36.5	36.5	35.2	31.2	27.2	23.3	19.3	34.3	3.72	34.3	34.3	32.9	28.9	24.9	21.0	17.0
1200	72	45.4	3.60	27.2	23.7	20.2	16.7	12.2	-	-	42.2	3.82	25.5	22.0	18.5	15.0	11.5	-	-
	67	40.6	3.51	33.0	29.5	26.0	22.5	19.0	15.5	12.0	37.9	3.73	31.8	28.3	24.8	21.3	17.8	14.3	10.8
	62	36.2	3.44	36.2	35.2	31.7	28.2	24.7	21.2	17.7	33.6	3.64	33.6	33.1	29.6	26.1	22.6	19.1	15.6
	57	35.7	3.49	35.7	35.7	33.0	29.5	26.0	22.5	19.0	33.7	3.70	33.7	33.7	30.9	27.4	23.9	20.4	16.9
1050	72	43.2	3.57	24.6	21.6	18.5	-	12.5	-	-	40.1	3.78	22.9	19.9	16.9	13.8	10.8	-	-
	67	38.7	3.48	29.9	26.9	23.8	20.8	17.8	14.7	11.7	36.1	3.69	28.7	25.7	22.6	19.6	16.6	13.5	10.5
	62	34.5	3.41	33.9	32.1	29.0	26.0	23.0	19.9	16.9	32.0	3.61	31.6	30.0	27.0	23.9	20.9	17.9	14.9
	57	34.0	3.47	34.0	32.9	30.3	27.2	24.2	21.2	18.1	32.1	3.67	32.1	30.9	28.2	25.1	22.1	19.1	16.0
900	72	41.1	3.54	22.0	19.4	16.8	14.3	11.7	-	-	38.0	3.75	20.4	17.8	15.2	12.7	10.1	-	-
	67	36.7	3.45	26.8	24.2	21.7	19.1	16.5	14.0	11.4	34.2	3.66	25.6	23.0	20.4	17.9	15.3	12.7	10.2
	62	32.8	3.39	31.5	28.9	26.4	23.8	21.2	18.7	16.1	30.3	3.58	29.5	26.9	24.4	21.8	19.2	16.7	14.1
	57	32.3	3.44	32.3	30.1	27.5	24.9	22.4	19.8	17.2	30.4	3.64	30.4	28.0	25.4	22.9	20.3	17.7	15.2

- These capacities are gross ratings. For net capacity, determine the kW of the supply air blower from the SUPPLY AIR BLOWER PERFORMANCE Tables, multiply this value by 3.415 MBH/kW to determine the motor heat, and deduct this heat from the gross capacity of the unit.
- These ratings include the compressor and the condenser fan motors but not the supply air blower motor. The total condenser fan motor power input is 0.36kW. Refer to SUPPLY AIR BLOWER PERFORMANCE Tables for the kW of the supply air blower motor.

NOMINAL RATING

TABLE 6: DH048 COOLING CAPACITIES (4 TON)

AIR ON EVAPORATOR COIL		TEMPERATURE OF AIR ON CONDENSER COIL																		
		85°F										95°F								
		TOTAL CAP. ¹ MBH	POWER INPUT ² kW	SENSIBLE CAPACITY ¹								TOTAL CAP. ¹ MBH	POWER INPUT ² kW	SENSIBLE CAPACITY ¹						
				ENTERING DRY BULB, °F										ENTERING DRY BULB, °F						
CFM	WB °F			86	83	80	77	74	71	68			86	83	80	77	74	71	68	
2000	72	59	3.3	46	40	34	28	23	-	-	55	3.5	43	37	32	26	20	-	-	
	67	53	3.2	53	49	43	38	32	26	21	49	3.4	49	47	41	35	30	24		
	62	47	3.2	47	47	47	42	36	30	25	44	3.4	44	44	44	38	32	26		
	57	47	3.1	47	47	47	41	35	29	24	43	3.3	43	43	43	37	31	26		
1800	72	58	3.3	42	37	32	27	22	-	-	54	3.5	40	35	30	25	20	-	-	
	67	53	3.2	50	46	41	35	30	25	20	48	3.4	47	44	39	33	28	23		
	62	47	3.2	47	47	46	41	36	31	26	43	3.4	43	43	43	38	33	28		
	57	46	3.1	46	46	46	41	35	30	25	42	3.3	42	42	42	37	32	27		
1600	72	57	3.3	39	34	30	25	21	-	-	53	3.5	37	33	28	23	19	-	-	
	67	52	3.2	47	42	38	33	29	24	19	48	3.4	45	41	36	32	27	22		
	62	46	3.2	46	46	45	41	36	32	27	42	3.4	42	42	43	39	34	30		
	57	45	3.1	45	45	45	40	36	31	27	41	3.3	41	41	41	37	32	28		
1400	72	54	3.2	35	31	27	23	19	-	-	51	3.5	34	30	26	22	17	-	-	
	67	49	3.1	43	39	35	31	27	23	19	45	3.4	41	37	33	29	25	21		
	62	43	3.1	43	43	42	38	34	30	26	40	3.4	40	40	40	36	32	28		
	57	43	3.1	43	43	41	37	33	29	25	39	3.3	39	39	38	34	30	26		
1200	72	51	3.2	32	29	25	22	18	-	-	48	3.5	30	27	23	20	16	-	-	
	67	46	3.1	39	35	32	28	25	21	18	42	3.5	37	34	30	27	23	20		
	62	41	3.1	41	41	38	35	31	28	24	38	3.4	38	38	36	33	29	26		
	57	40	3.0	40	40	38	34	31	27	24	37	3.4	37	37	35	31	28	24		

AIR ON EVAPORATOR COIL		TEMPERATURE OF AIR ON CONDENSER COIL																		
		105°F										115°F								
		TOTAL CAP. ¹ MBH	POWER INPUT ² kW	SENSIBLE CAPACITY ¹								TOTAL CAP. ¹ MBH	POWER INPUT ² kW	SENSIBLE CAPACITY ¹						
				ENTERING DRY BULB, °F										ENTERING DRY BULB, °F						
CFM	WB °F			86	83	80	77	74	71	68			86	83	80	77	74	71	68	
2000	72	50	3.8	41	35	30	24	18	-	-	45	4.0	39	33	28	22	16	-	-	
	67	45	3.7	45	44	39	33	27	22	16	40	4.0	40	40	37	31	25	20		
	62	39	3.6	39	39	39	34	28	22	17	35	3.8	35	35	35	30	24	18		
	57	39	3.6	39	39	39	33	27	22	16	35	3.8	35	35	35	29	23	18		
1800	72	50	3.8	38	33	28	23	18	-	-	45	4.0	36	31	26	21	16	-	-	
	67	44	3.7	44	41	36	31	26	21	16	40	4.0	40	39	34	29	24	19		
	62	39	3.6	39	39	40	35	30	25	20	35	3.9	35	35	37	32	27	22		
	57	38	3.6	38	38	38	33	28	23	18	34	3.8	34	34	34	29	24	19		
1600	72	49	3.8	35	31	26	21	17	-	-	45	4.1	33	29	24	20	15	-	-	
	67	44	3.7	43	39	34	30	25	20	16	40	4.1	40	37	32	27	23	18		
	62	39	3.6	39	39	41	37	32	27	23	35	3.9	35	35	39	34	30	25		
	57	38	3.6	38	38	38	33	29	24	19	34	3.8	34	34	34	30	25	20		
1400	72	47	3.8	32	28	24	20	16	-	-	43	4.0	30	26	22	18	14	-	-	
	67	42	3.7	39	35	31	27	23	19	15	38	4.0	37	34	29	25	21	17		
	62	37	3.6	37	37	38	33	29	25	21	33	3.8	33	33	35	31	27	23		
	57	36	3.5	36	36	35	31	27	23	18	33	3.7	33	33	31	27	23	19		
1200	72	44	3.7	29	25	22	18	15	-	-	41	3.9	27	24	20	17	13	-	-	
	67	40	3.7	36	32	29	25	21	18	14	36	3.9	34	30	27	23	20	16		
	62	35	3.6	35	35	34	30	27	23	20	32	3.8	32	32	32	28	25	21		
	57	34	3.5	34	34	32	28	25	21	18	31	3.7	31	31	29	25	22	18		

- These capacities are gross ratings. For net capacity, determine the kW of the supply air blower from the SUPPLY AIR BLOWER PERFORMANCE Tables, multiply this value by 3.415 MBH/kW to determine the motor heat, and deduct this heat from the gross capacity of the unit.
- These ratings include the compressor and the condenser fan motors but not the supply air blower motor. The total condenser fan motor power input is 0.36kW. Refer to SUPPLY AIR BLOWER PERFORMANCE Tables for the kW of the supply air blower motor.

NOMINAL RATING

TABLE 7: DH060 COOLING CAPACITIES (5 TON)

AIR ON EVAPORATOR COIL		TEMPERATURE OF AIR ON CONDENSER COIL																			
		85°F										95°F									
		TOTAL CAP. ¹ MBH	POWER INPUT ² kW	SENSIBLE CAPACITY ¹								TOTAL CAP. ¹ MBH	POWER INPUT ² kW	SENSIBLE CAPACITY ¹							
				ENTERING DRY BULB, °F										ENTERING DRY BULB, °F							
CFM	WB °F			86	83	80	77	74	71	68			86	83	80	77	74	71	68		
2500	72	82	4.3	56	50	43	37	30	-	-	76	4.6	54	48	41	34	28	-	-		
	67	70	4.2	67	61	54	48	41	34	28	65	4.5	65	58	51	45	38	31	25		
	62	67	4.0	67	67	66	59	52	46	39	62	4.5	62	62	62	55	49	42	35		
	57	66	4.0	66	66	66	59	52	46	39	61	4.4	61	61	61	54	47	41	34		
2250	72	78	4.3	53	47	41	35	29	-	-	73	4.6	50	44	38	32	26	-	-		
	67	67	4.2	63	57	51	45	39	33	27	62	4.5	60	54	48	42	36	30	24		
	62	64	4.0	64	64	62	56	50	44	38	60	4.4	60	60	59	53	47	41	35		
	57	63	4.0	63	63	63	57	51	45	39	58	4.4	58	58	58	52	46	40	34		
2000	72	75	4.3	49	43	38	33	27	-	-	70	4.6	46	41	36	30	25	-	-		
	67	64	4.2	58	53	48	42	37	32	26	60	4.5	56	50	45	39	34	29	23		
	62	61	4.0	61	61	58	52	47	42	36	57	4.4	57	57	55	50	45	39	34		
	57	60	4.0	60	60	59	54	49	43	38	56	4.4	56	56	56	50	45	39	34		
1750	72	72	4.3	44	40	35	30	25	-	-	67	4.6	43	38	33	28	24	-	-		
	67	62	4.2	53	49	44	39	34	30	25	58	4.5	51	46	41	37	32	27	22		
	62	59	4.0	59	57	53	48	44	39	34	55	4.4	55	54	51	46	42	37	32		
	57	58	4.0	58	57	55	50	45	40	36	54	4.4	54	54	51	47	42	37	32		
1500	72	69	4.2	40	36	32	28	24	-	-	65	4.6	39	34	30	26	22	-	-		
	67	59	4.1	48	44	40	36	32	28	23	56	4.5	46	42	38	34	30	26	21		
	62	56	4.0	56	53	49	44	40	36	32	53	4.4	53	51	47	43	39	35	30		
	57	55	4.0	55	54	50	46	42	37	33	52	4.4	52	51	47	43	39	35	30		

AIR ON EVAPORATOR COIL		TEMPERATURE OF AIR ON CONDENSER COIL																	
		105°F										115°F							
		TOTAL CAP. ¹ MBH	POWER INPUT ² kW	SENSIBLE CAPACITY ¹								TOTAL CAP. ¹ MBH	POWER INPUT ² kW	SENSIBLE CAPACITY ¹					
				ENTERING DRY BULB, °F										ENTERING DRY BULB, °F					
CFM	WB °F			86	83	80	77	74	71	68			86	83	80	77	74	71	68
2500	72	68	5.0	51	44	38	31	25	-	-	61	5.3	48	41	35	28	21	-	-
	67	60	4.8	60	55	49	42	35	29	22	55	5.1	55	53	46	39	33	26	20
	62	56	4.8	56	56	56	49	43	36	29	50	5.1	50	50	50	43	37	30	23
	57	55	4.7	55	55	55	48	42	35	28	49	5.0	49	49	49	43	36	29	23
2250	72	67	4.9	48	42	36	30	24	-	-	60	5.3	45	39	33	27	21	-	-
	67	58	4.8	57	52	46	40	34	28	22	54	5.1	53	50	44	38	32	26	20
	62	55	4.7	55	55	54	48	42	36	30	49	5.0	49	49	49	43	37	31	25
	57	54	4.7	54	54	53	47	41	35	29	49	5.0	49	49	49	43	37	31	25
2000	72	65	4.9	44	39	33	28	23	-	-	60	5.2	42	36	31	26	20	-	-
	67	57	4.8	54	48	43	38	32	27	22	54	5.1	52	47	41	36	30	25	20
	62	53	4.7	53	53	52	46	41	36	30	49	5.0	49	49	48	43	37	32	26
	57	52	4.7	52	52	52	46	41	36	30	48	5.0	48	48	48	42	37	32	26
1750	72	62	4.9	40	35	31	26	21	-	-	56	5.2	38	33	28	24	19	-	-
	67	54	4.8	49	44	40	35	30	25	21	51	5.0	47	42	38	33	28	23	19
	62	51	4.7	51	50	48	43	38	33	29	46	5.0	46	46	44	39	34	30	25
	57	50	4.6	50	50	48	43	38	33	29	46	4.9	46	46	44	39	34	29	25
1500	72	59	4.9	36	32	28	24	20	-	-	53	5.2	34	30	26	22	18	-	-
	67	52	4.7	44	40	36	32	28	24	20	48	5.0	43	38	34	30	26	22	18
	62	48	4.7	48	47	43	39	35	31	27	43	4.9	43	43	40	36	32	27	23
	57	47	4.6	47	47	43	39	35	31	27	43	4.9	43	43	40	36	31	27	23

- These capacities are gross ratings. For net capacity, determine the kW of the supply air blower from the SUPPLY AIR BLOWER PERFORMANCE Tables, multiply this value by 3.415 MBH/kW to determine the motor heat, and deduct this heat from the gross capacity of the unit.
- These ratings include the compressor and the condenser fan motors but not the supply air blower motor. The total condenser fan motor power input is 0.36kW. Refer to SUPPLY AIR BLOWER PERFORMANCE Tables for the kW of the supply air blower motor.

NOMINAL RATING

TABLE 8: SUPPLY AIR BLOWER PERFORMANCE (DH036 BELT DRIVE) - SIDE DUCT APPLICATION

Air Flow (CFM)	Available External Static Pressure - IWG ¹																			
	0.2		0.4		0.6		0.8		1.0		1.2		1.4		1.6		1.8		2.0	
	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP
	Field Supplied Drive				Standard Drive Option								High Static Drive Option							
800	679	0.34	762	0.41	842	0.49	918	0.57	992	0.66	1063	0.74	1131	0.83	1197	0.93	1260	1.02	1322	1.12
1000	703	0.39	786	0.47	866	0.54	942	0.62	1016	0.71	1087	0.79	1155	0.88	1221	0.98	1284	1.07	1345	1.17
1200	733	0.44	817	0.52	896	0.60	973	0.68	1047	0.76	1118	0.85	1186	0.94	1252	1.03	1315	1.12	1376	1.22
1400	770	0.52	853	0.60	933	0.67	1010	0.76	1083	0.84	1154	0.93	1222	1.02	1288	1.11	1352	1.20	1413	1.30
1600	811	0.64	895	0.71	974	0.79	1051	0.87	1125	0.96	1196	1.04	1264	1.13	1330	1.23	1393	1.32	1454	1.42
	Field Supplied Drive																			

1. Blower performance includes gas heat exchangers and 1" filters. See STATIC RESISTANCE table for additional applications.
2. See RPM SELECTION table to determine desired motor sheave setting and to determine the maximum continuous BHP.
3. kW = BHP x 0.932.

TABLE 9: SUPPLY AIR BLOWER PERFORMANCE (DH036 BELT DRIVE) - BOTTOM DUCT APPLICATION

Air Flow (CFM)	Available External Static Pressure - IWG ¹																			
	0.2		0.4		0.6		0.8		1.0		1.2		1.4		1.6		1.8		2.0	
	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP
	Field Supplied Drive				Standard Drive Option								High Static Drive Option							
800	662	0.35	753	0.42	840	0.50	923	0.58	1003	0.66	1081	0.75	1155	0.83	1227	0.92	1296	1.02	1362	1.11
1000	688	0.40	779	0.47	866	0.55	949	0.63	1029	0.71	1107	0.80	1181	0.88	1253	0.97	1322	1.07	1388	1.16
1200	722	0.45	812	0.53	899	0.60	983	0.68	1063	0.76	1140	0.85	1215	0.93	1286	1.03	1355	1.12	1422	1.21
1400	761	0.53	852	0.60	939	0.68	1022	0.76	1103	0.84	1180	0.92	1254	1.01	1326	1.10	1395	1.20	1462	1.29
1600	807	0.65	897	0.72	984	0.79	1068	0.87	1148	0.95	1225	1.04	1300	1.13	1371	1.22	1440	1.31	1507	1.40
	Field Supplied Drive																			

1. Blower performance includes gas heat exchangers and 1" filters. See STATIC RESISTANCE table for additional applications.
2. See RPM SELECTION table to determine desired motor sheave setting and to determine the maximum continuous BHP.
3. kW = BHP x 0.932.

TABLE 10: SUPPLY AIR BLOWER PERFORMANCE (DH048 BELT DRIVE) - SIDE DUCT APPLICATION

Air Flow (CFM)	Available External Static Pressure - IWG ¹																			
	0.2		0.4		0.6		0.8		1.0		1.2		1.4		1.6		1.8		2.0	
	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP
	Field Supplied Drive						Standard Drive Option								High Static Drive Option					
1000	703	0.39	786	0.47	866	0.54	942	0.62	1016	0.71	1087	0.79	1155	0.88	1221	0.98	1284	1.07	1345	1.17
1200	733	0.44	817	0.52	896	0.60	973	0.68	1047	0.76	1118	0.85	1186	0.94	1252	1.03	1315	1.12	1376	1.22
1400	770	0.52	853	0.60	933	0.67	1010	0.76	1083	0.84	1154	0.93	1222	1.02	1288	1.11	1352	1.20	1413	1.30
1600	811	0.64	895	0.71	974	0.79	1051	0.87	1125	0.96	1196	1.04	1264	1.13	1330	1.23	1393	1.32	1454	1.42
1800	857	0.80	940	0.87	1020	0.95	1097	1.03	1171	1.11	1242	1.20	1310	1.29	1375	1.38	1439	1.48	1500	1.58
2000	907	1.00	990	1.07	1070	1.15	1146	1.23	1220	1.31	1291	1.40	1359	1.49	1425	1.58	1488	1.68	1550	1.77
	FS ⁴																			

1. Blower performance includes gas heat exchangers and 1" filters. See STATIC RESISTANCE table for additional applications.
2. See RPM SELECTION table to determine desired motor sheave setting and to determine the maximum continuous BHP.
3. kW = BHP x 0.932.
4. Field Supplied Drive.

TABLE 11: SUPPLY AIR BLOWER PERFORMANCE (DH048 BELT DRIVE) - BOTTOM DUCT APPLICATION

Air Flow (CFM)	Available External Static Pressure - IWG ¹																			
	0.2		0.4		0.6		0.8		1.0		1.2		1.4		1.6		1.8		2.0	
	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP
	Field Supplied Drive						Standard Drive Option										High Static Drive Option			
1000	688	0.40	779	0.47	866	0.55	949	0.63	1029	0.71	1107	0.80	1181	0.88	1253	0.97	1322	1.07	1388	1.16
1200	722	0.45	812	0.53	899	0.60	983	0.68	1063	0.76	1140	0.85	1215	0.93	1286	1.03	1355	1.12	1422	1.21
1400	761	0.53	852	0.60	939	0.68	1022	0.76	1103	0.84	1180	0.92	1254	1.01	1326	1.10	1395	1.20	1462	1.29
1600	807	0.65	897	0.72	984	0.79	1068	0.87	1148	0.95	1225	1.04	1300	1.13	1371	1.22	1440	1.31	1507	1.40
1800	856	0.80	947	0.87	1034	0.95	1118	1.02	1198	1.11	1275	1.19	1349	1.28	1421	1.37	1490	1.46	1557	1.56
2000	910	0.99	1001	1.06	1088	1.14	1172	1.22	1252	1.30	1329	1.39	1403	1.47	1475	1.56	1544	1.66	1611	1.75
	Field Supplied Drive																			

1. Blower performance includes gas heat exchangers and 1" filters. See STATIC RESISTANCE table for additional applications.
2. See RPM SELECTION table to determine desired motor sheave setting and to determine the maximum continuous BHP.
3. kW = BHP x 0.932.

TABLE 12: SUPPLY AIR BLOWER PERFORMANCE (DH060 BELT DRIVE) - SIDE DUCT APPLICATION

Air Flow (CFM)	Available External Static Pressure - IWG ¹																			
	0.2		0.4		0.6		0.8		1.0		1.2		1.4		1.6		1.8		2.0	
	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP
	Field Supplied Drive						Standard Drive Option								High Static Drive Option					
1200	733	0.44	817	0.52	896	0.60	973	0.68	1047	0.76	1118	0.85	1186	0.94	1252	1.03	1315	1.12	1376	1.22
1400	770	0.52	853	0.60	933	0.67	1010	0.76	1083	0.84	1154	0.93	1222	1.02	1288	1.11	1352	1.20	1413	1.30
1600	811	0.64	895	0.71	974	0.79	1051	0.87	1125	0.96	1196	1.04	1264	1.13	1330	1.23	1393	1.32	1454	1.42
1800	857	0.80	940	0.87	1020	0.95	1097	1.03	1171	1.11	1242	1.20	1310	1.29	1375	1.38	1439	1.48	1500	1.58
2000	907	1.00	990	1.07	1070	1.15	1146	1.23	1220	1.31	1291	1.40	1359	1.49	1425	1.58	1488	1.68	1550	1.77
2200	960	1.24	1043	1.31	1123	1.39	1199	1.47	1273	1.55	1344	1.64	1412	1.73	1478	1.82	1541	1.92	1602	2.01
2400	1015	1.51	1099	1.59	1178	1.66	1255	1.74	1329	1.83	1400	1.92	1468	2.01	1534	2.10	1597	2.19	1658	2.29
2600	1074	1.83	1157	1.90	1237	1.98	1314	2.06	1387	2.14	1458	2.23	-	-	-	-	-	-	-	-

1. Blower performance includes gas heat exchangers and 1" filters. See STATIC RESISTANCE table for additional applications.
2. See RPM SELECTION table to determine desired motor sheave setting and to determine the maximum continuous BHP.
3. kW = BHP x 0.932.

TABLE 13: SUPPLY AIR BLOWER PERFORMANCE (DH060 BELT DRIVE) - BOTTOM DUCT APPLICATION

Air Flow (CFM)	Available External Static Pressure - IWG ¹																			
	0.2		0.4		0.6		0.8		1.0		1.2		1.4		1.6		1.8		2.0	
	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP
	Field Supplied Drive						Standard Drive Option								High Static Drive Option					
1200	722	0.45	812	0.53	899	0.60	983	0.68	1063	0.76	1140	0.85	1215	0.93	1286	1.03	1355	1.12	1422	1.21
1400	761	0.53	852	0.60	939	0.68	1022	0.76	1103	0.84	1180	0.92	1254	1.01	1326	1.10	1395	1.20	1462	1.29
1600	807	0.65	897	0.72	984	0.79	1068	0.87	1148	0.95	1225	1.04	1300	1.13	1371	1.22	1440	1.31	1507	1.40
1800	856	0.80	947	0.87	1034	0.95	1118	1.02	1198	1.11	1275	1.19	1349	1.28	1421	1.37	1490	1.46	1557	1.56
2000	910	0.99	1001	1.06	1088	1.14	1172	1.22	1252	1.30	1329	1.39	1403	1.47	1475	1.56	1544	1.66	1611	1.75
2200	968	1.23	1059	1.30	1146	1.37	1229	1.45	1309	1.53	1387	1.62	1461	1.71	1533	1.80	1602	1.89	1668	1.99
2400	1029	1.50	1119	1.57	1206	1.65	1290	1.72	1370	1.81	1448	1.89	1522	1.98	1593	2.07	1663	2.16	1729	2.26
2600	1093	1.81	1183	1.88	1270	1.95	1354	2.03	1434	2.11	1511	2.20	1586	2.29	-	-	-	-	-	-
	Field Supplied Drive																			

1. Blower performance includes gas heat exchangers and 1" filters. See STATIC RESISTANCE table for additional applications.
2. See RPM SELECTION table to determine desired motor sheave setting and to determine the maximum continuous BHP.
3. kW = BHP x 0.932.

TABLE 14: SUPPLY AIR BLOWER PERFORMANCE (3-5 TON) SIDE DUCT APPLICATION

UNIT TONNAGE	MOTOR ¹ SPEED	AVAILABLE EXTERNAL STATIC PRESSURE - IWG ²																	
		0.2		0.3		0.4		0.5		0.6		0.7		0.8		0.9		1.0	
		CFM	WATTS	CFM	WATTS	CFM	WATTS	CFM	WATTS	CFM	WATTS	CFM	WATTS	CFM	WATTS	CFM	WATTS	CFM	WATTS
3 ³	HI	1535	320	1493	335	1452	349	1416	363	1377	376	1340	390	1299	403	1260	417	1219	430
	MED/HI	1444	263	1398	276	1355	290	1315	303	1271	316	1227	329	1179	343	1125	358	1053	374
	MED	1300	208	1254	221	1211	234	1166	246	1119	258	1070	272	1006	288	939	303	897	313
	MED/LOW	1197	171	1149	183	1102	195	1050	207	996	220	930	235	869	248	-	-	-	-
	LOW	1049	130	968	134	908	145	838	158	-	-	-	-	-	-	-	-	-	-
4 ³	HI	2056	636	2017	696	1978	714	1942	734	1906	749	1864	764	1815	769	1728	743	1582	685
	MED/HI	1866	539	1832	557	1795	571	1754	585	1722	602	1679	619	1636	638	1582	653	1508	639
	MED	1680	408	1641	426	1594	438	1558	455	1517	472	1469	490	1415	505	1370	521	1337	536
	MED/LOW	1582	362	1541	380	1495	391	1465	406	1426	423	1377	440	1326	455	1292	469	1247	485
	LOW	1300	223	1258	237	1202	247	-	-	-	-	-	-	-	-	-	-	-	-
5 ³	HI	2256	883	2258	931	2247	950	2223	964	2182	979	2125	971	2044	940	1958	898	1864	854
	MED/HI	2145	771	2127	784	2119	808	2089	826	2051	844	2014	859	1965	861	1896	843	1801	806
	MED	2020	637	1999	656	1985	675	1947	696	1910	715	1876	730	1832	740	1793	756	1725	748
	MED/LOW	1757	413	1713	432	1677	451	1639	468	1597	479	1559	497	1521	513	1472	523	-	-
	LOW	1570	327	1536	339	1499	356	-	-	-	-	-	-	-	-	-	-	-	-

1. Factory set on medium speed tap.
2. Includes allowances for a wet evaporator coil, 1" filters, and the heat exchangers. Refer to STATIC RESISTANCES Table for resistance values.
3. Side Duct application (230 Volts)

TABLE 15: SUPPLY AIR BLOWER PERFORMANCE (3-5 TON) BOTTOM DUCT APPLICATION

UNIT TONNAGE	MOTOR ¹ SPEED	AVAILABLE EXTERNAL STATIC PRESSURE - IWG ²																	
		0.2		0.3		0.4		0.5		0.6		0.7		0.8		0.9		1.0	
		CFM	WATTS	CFM	WATTS	CFM	WATTS	CFM	WATTS	CFM	WATTS	CFM	WATTS	CFM	WATTS	CFM	WATTS	CFM	WATTS
3 ³	HI	1483	320	1442	335	1403	349	1368	363	1330	376	1295	390	1255	403	1218	417	1178	430
	MED/HI	1395	263	1350	276	1309	290	1270	303	1228	316	1185	329	1139	343	1087	358	1018	374
	MED	1256	208	1212	221	1170	234	1127	246	1081	258	1035	272	973	288	908	303	868	313
	MED/LOW	1157	171	1111	183	1065	195	1015	207	963	220	899	235	841	248	-	-	-	-
	LOW	1015	130	936	134	878	145	810	158	-	-	-	-	-	-	-	-	-	-
4 ³	HI	1985	636	1947	696	1909	714	1875	734	1840	749	1800	764	1752	769	1668	743	1528	685
	MED/HI	1802	539	1768	557	1733	571	1694	585	1662	602	1621	619	1580	638	1528	653	1456	639
	MED	1622	408	1585	426	1539	438	1505	455	1465	472	1419	490	1367	505	1324	521	1291	536
	MED/LOW	1528	362	1489	380	1444	391	1415	406	1377	423	1330	440	1281	455	1248	469	1205	485
	LOW	1256	223	1216	237	1161	247	-	-	-	-	-	-	-	-	-	-	-	-
5 ³	HI	2177	883	2179	931	2169	950	2145	964	2106	979	2051	971	1973	940	1890	898	1800	854
	MED/HI	2071	771	2053	784	2045	808	2016	826	1980	844	1944	859	1897	861	1830	843	1739	806
	MED	1950	637	1929	656	1916	675	1880	696	1844	715	1811	730	1768	740	1731	756	1665	748
	MED/LOW	1697	413	1654	432	1619	451	1583	468	1542	479	1506	497	1469	513	-	-	-	-
	LOW	1516	327	1484	339	1448	356	-	-	-	-	-	-	-	-	-	-	-	-

1. Factory set on medium speed tap.
2. Includes allowances for a wet evaporator coil, 1" filters, and the heat exchangers. Refer to STATIC RESISTANCES Table for resistance values.
3. Bottom Duct application (230 Volts)

TABLE 16: BELT DRIVE RPM SELECTION

Size (Tons)	HP	Max BHP	Motor Sheave	Blower Sheave	5 Turns Open	4 Turns Open	3 Turns Open	2 Turns Open	1 Turn Open	Fully Closed
036 (3)	1.5	1.73	1VL44	AK64	805	865	920	980	1035	1095
	1.5	1.73	1VP56	AK66	1115	1170	1225	1280	1335	1390
048 (4)	1.5	1.73	1VL44	AK56	930	995	1060	1130	1195	1260
	1.5	1.73	1VP56	AK61	1210	1270	1330	1390	1455	1515
060 (5)	1.5	1.73	1VL44	AK56	930	995	1060	1130	1195	1260
	2	2.3	1VP56	AK56	1325	1395	1460	1525	1590	1660

TABLE 17: BELT DRIVE BLOWER MOTOR AND DRIVE DATA

Size (Tons)	Motor					Motor Sheave			Blower Sheave			Belt
	HP	RPM	Eff.	SF	Frame	Datum Dia. (in.)	Bore (in.)	Model	Datum Dia. (in.)	Bore (in.)	Model	
036 (3.0)	1-1/2	1725	0.8	1.15	56	2.8 - 3.8	7/8	1VL44	6.0	1	AK64	A37
	1-1/2	1725	0.8	1.15	56	4.0 - 5.0	7/8	1VP56	6.2	1	AK66	A39
048 (4.0)	1-1/2	1725	0.8	1.15	56	2.8 - 3.8	7/8	1VL44	5.2	1	AK56	A36
	1-1/2	1725	0.8	1.15	56	4.0 - 5.0	7/8	1VP56	5.7	1	AK61	A38
060 (5.0)	1-1/2	1725	0.8	1.15	56	2.8 - 3.8	7/8	1VL44	5.2	1	AK56	A36
	2	1725	0.8	1.15	56	4.0 - 5.0	7/8	1VP56	5.2	1	AK56	A38

TABLE 18: STATIC RESISTANCES

Description		Resistance, IWG										
		CFM										
		1000	1200	1400	1600	1800	2000	2200	2400	2600	2800	3000
Economizer ^{1 2}		0.07	0.08	0.09	0.11	0.13	0.15	0.17	0.20	0.23	0.26	0.30
Electric Heaters ¹	7 - 15 kW	0.04	0.05	0.06	0.07	0.08	0.10	0.12	0.14	0.16	0.19	0.22
	20 - 30 kW	0.06	0.07	0.08	0.09	0.11	0.13	0.15	0.17	0.20	0.23	0.26
Bottom Duct Connections ¹		0.06	0.07	0.08	0.09	0.10	0.11	0.12	0.14	0.16	0.19	0.22

1. Deduct these resistance values from the available external static pressure shown in SUPPLY AIR BLOWER PERFORMANCE Tables.

2. The pressure through the economizer is greater for 100% outdoor air than for 100% return air. If the resistance of the return air duct system is less than 0.25 IWG, the unit will deliver less CFM during full economizer operation.

Drive Selection

1. Determine desired airflow.
2. Calculate or measure the amount of external static pressure.
3. Using the operating point determined from steps 1 & 2, locate this point on the appropriate supply air blower performance table. (Linear interpolation may be necessary.)
4. Noting the RPM and BHP from step 3, locate the appropriate model and drive on the RPM selection table.
5. Review the BHP compared to the motor options available. Select the appropriate motor.
6. Review the RPM range for the motor options available. Select the appropriate drive if multiple drives are available for the chosen motor.
7. Determine turns open to obtain the desired operation point.

Example

1. 19000 CFM
2. 5.4 iwg
3. Using the supply air blower performance table below, the following data point was located: 1150 RPM & 36 BHP.
4. Using the RPM selection table below, Size X and Model Y is found.
5. 36 BHP exceeds the maximum continuous BHP rating of the 30 HP motor. The 40 HP motor is required.
6. 1150 RPM is within the range of the 30 & 40 HP drives, but step 5 requires the 40 HP motor.
7. Using the 40 HP motor and drive, 5.5 turns open will achieve 1150 RPM.

Example Supply Air Blower Performance


Air Flow (CFM)	Available External Static Pressure - IWG																			
	3.0		3.4		3.8		4.2		4.6		5.0		5.4		5.8		6.2		6.6	
	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP	RPM	BHP
	30 HP & Field Supplied Drive						Standard 30 HP & Drive						Alternate 40 HP & Drive							
18000	800	10.00	850	14.00	900	18.00	950	22.00	1000	26.00	1050	30.00	1100	34.00	1150	38.00	1200	42.00	1250	46.00
19000	850	12.00	900	16.00	950	20.00	1000	24.00	1050	28.00	1100	32.00	1150	36.00	1200	40.00	1250	44.00	1300	48.00
20000	900	14.00	950	18.00	1000	22.00	1050	26.00	1100	30.00	1150	34.00	1200	38.00	1250	42.00	1300	46.00	1350	50.00
21000	950	16.00	1000	20.00	1050	24.00	1100	28.00	1150	32.00	1200	36.00	1250	40.00	1300	44.00	1350	48.00	1400	52.00

Table X: RPM Selection

Size (Tons)	Model	HP	Max BHP	Motor Sheave	Blower Sheave	6 Turns Open	5 Turns Open	4 Turns Open	3 Turns Open	2 Turns Open	1 Turn Open	Fully Closed
X	Y	30	34.50	1VL51	BK99	1000	1025	1045	1060	1110	1150	N/A
		40	46.00	1VL63	BK67	1125	1175	1250	1325	1400	1475	N/A

Altitude/Temperature Correction Factors

Air Temp.	Altitude (Ft.)										
	0	1000	2000	3000	4000	5000	6000	7000	8000	9000	10000
40	1.060	1.022	0.986	0.950	0.916	0.882	0.849	0.818	0.788	0.758	0.729
50	1.039	1.002	0.966	0.931	0.898	0.864	0.832	0.802	0.772	0.743	0.715
60	1.019	0.982	0.948	0.913	0.880	0.848	0.816	0.787	0.757	0.729	0.701
70	1.000	0.964	0.930	0.896	0.864	0.832	0.801	0.772	0.743	0.715	0.688
80	0.982	0.947	0.913	0.880	0.848	0.817	0.787	0.758	0.730	0.702	0.676
90	0.964	0.929	0.897	0.864	0.833	0.802	0.772	0.744	0.716	0.689	0.663
100	0.946	0.912	0.880	0.848	0.817	0.787	0.758	0.730	0.703	0.676	0.651

**TABLE 19: ELECTRIC HEATER CFM LIMITATIONS**

UNIT MODEL SIZE NOMINAL TONS	VOLTAGE	MINIMUM SUPPLY AIR CFM					
		HEATER SIZE NOMINAL KW					
		5	7	10	15	20	30
036 (3)	208/230-1-60	900	900	900	900	900	-
	208/230-3-60	900	900	900	900	900	-
	460-3-60	-	900	900	900	900	-
	600-3-60	-	-	900	900	900	-
048 (4)	208/230-1-60	1200	1200	1200	1200	1200	-
	208/230-3-60	1200	1200	1200	1200	1200	-
	460-3-60	-	1200	1200	1200	1200	-
	600-3-60	-	-	1200	1200	1200	-
060 (5)	208/230-1-60	1500	1500	1500	1500	1500	1500
	208/230-3-60	1500	1500	1500	1500	1500	1500
	460-3-60	-	1500	1500	1500	1500	1500
	600-3-60	-	-	1500	1500	1500	1500

TABLE 20: ELECTRICAL DATA - DH036, 048 & 060 DIRECT DRIVE W/O POWERED CONVENIENCE OUTLET

Size (Tons)	Volt	Compressors (each)			OD Fan Motors (each)	Supply Blower Motor	Pwr Conv Outlet	Electric Heat Option				MCA ¹ (Amps)	Max Fuse ² / Breaker ³ Size (Amps)
		RLA	LRA	MCC				Model	kW	Stages	Amps		
036 (3.0)	208-3-60	13.1	110.0	20.5	2.3	6.0	0.0	None	-	-	-	24.7	35
								E05	4.0	1	11.1	24.7	35
								E07	5.6	1	15.5	26.9	35
								E10	8.0	1	22.2	35.3	40
								E15	11.9	2	33.0	48.8	50
								E20	15.9	2	44.1	62.7	70
	230-3-60	13.1	110.0	20.5	2.3	6.0	0.0	None	-	-	-	26.3	35
								E05	5.3	1	13.3	26.3	35
								E07	7.5	1	18.8	32.1	35
								E10	10.6	1	26.6	41.4	45
								E15	15.9	2	39.9	57.3	60
048 (4.0)	208-3-60	13.1	110.0	20.5	2.3	7.6	0.0	None	-	-	-	26.3	35
								E05	4.0	1	11.1	26.3	35
								E07	5.6	1	15.5	28.9	35
								E10	8.0	1	22.2	37.3	40
								E15	11.9	2	33.0	50.8	60
								E20	15.9	2	44.1	64.7	70
	230-3-60	13.1	110.0	20.5	2.3	7.6	0.0	None	-	-	-	26.3	35
								E05	5.3	1	13.3	26.3	35
								E07	7.5	1	18.8	32.1	35
								E10	10.6	1	26.6	41.4	45
								E15	15.9	2	39.9	57.3	60
060 (5.0)	208-3-60	16.0	137.0	25.0	2.3	7.6	0.0	None	-	-	-	29.9	40
								E05	4.0	1	11.1	29.9	40
								E07	5.6	1	15.5	29.9	40
								E10	8.0	1	22.2	37.3	45
								E15	11.9	2	33.0	50.8	60
								E20	15.9	2	44.1	64.7	70
								E30	22.2	2	61.6	86.5	90
	230-3-60	17.3	137.0	25.0	2.3	7.6	0.0	None	-	-	-	29.9	40
								E05	5.3	1	13.3	29.9	40
								E07	7.5	1	18.8	32.1	45
								E10	10.6	1	26.6	41.4	45
								E15	15.9	2	39.9	57.3	60
								E20	21.2	2	53.2	73.2	80
								E30	29.6	2	74.3	98.5	100

1. Minimum Circuit Ampacity.
2. Dual Element, Time Delay Type.
3. HACR type per NEC.

TABLE 21: ELECTRICAL DATA - DH036-060 BELT DRIVE W/O POWERED CONVENIENCE OUTLET

Size (Tons)	Volt	Compressors (each)			OD Fan Motors (each)	Supply Blower Motor	Pwr Conv Outlet	Electric Heat Option				MCA ¹ (Amps)	Max Fuse ² / Breaker ³ Size (Amps)
		RLA	LRA	MCC	FLA	FLA	FLA	Model	kW	Stages	Amps		
036 (3.0)	208-3-60	13.1	110.0	20.5	2.3	5.2	0.0	None	-	-	-	23.9	30
								E05	4.0	1	11.1	23.9	30
								E07	5.6	1	15.5	25.9	35
								E10	8.0	1	22.2	34.3	35
								E15	11.9	2	33.0	47.8	50
	230-3-60	13.1	110.0	20.5	2.3	5.2	0.0	E20	15.9	2	44.1	61.7	70
								None	-	-	-	23.9	30
								E05	5.3	1	13.3	23.9	30
								E07	7.5	1	18.8	29.1	35
								E10	10.6	1	26.6	38.4	40
	460-3-60	6.7	54.0	10.5	1.3	2.6	0.0	E15	15.9	2	39.9	54.3	60
								E20	21.2	2	53.2	70.2	80
								None	-	-	-	12.3	15
								E07	6.8	1	8.5	13.5	15
								E10	10.1	1	12.7	18.4	20
048 (4.0)	208-3-60	13.1	110.0	20.5	2.3	5.2	0.0	E15	13.6	2	17.1	23.7	25
								E20	19.5	2	24.5	32.6	35
								None	-	-	-	23.9	30
								E05	4.0	1	11.1	23.9	30
								E07	5.6	1	15.5	25.9	35
	230-3-60	13.1	110.0	20.5	2.3	5.2	0.0	E10	8.0	1	22.2	34.3	35
								E15	11.9	2	33.0	47.8	50
								E20	15.9	2	44.1	61.7	70
								None	-	-	-	23.9	30
								E05	5.3	1	13.3	23.9	30
	460-3-60	6.7	54.0	10.5	1.3	2.6	0.0	E07	7.5	1	18.8	29.1	35
								E10	10.6	1	26.6	38.4	40
								E15	15.9	2	39.9	54.3	60
								E20	21.2	2	53.2	70.2	80
								None	-	-	-	12.3	15
575-3-60	5.1	44.0	8.0	1.3	2.0	0.0	E07	6.8	1	8.5	13.5	15	
							E10	10.1	1	12.7	18.4	20	
							E15	13.6	2	17.1	23.7	25	
							E20	19.5	2	24.5	32.6	35	
							None	-	-	-	9.4	15	
060 (5.0)	208-3-60	16.0	137.0	25.0	2.3	5.2	0.0	E10	10.6	1	10.6	15.2	20
								E15	15.9	1	16.0	21.6	25
								E20	21.2	2	21.3	28.0	30
								None	-	-	-	27.5	35
								E05	4.0	1	11.1	27.5	35
	230-3-60	16.0	137.0	25.0	2.3	5.2	0.0	E07	5.6	1	15.5	27.5	35
								E10	8.0	1	22.2	34.3	40
								E15	11.9	2	33.0	47.8	50
								E20	15.9	2	44.1	61.7	70
								E30	22.2	2	61.6	83.5	90
	460-3-60	8.3	69.0	13.0	1.3	2.6	0.0	None	-	-	-	14.3	20
								E07	6.8	1	8.5	14.3	20
								E10	10.1	1	12.7	18.4	20
								E15	13.6	2	17.1	23.7	25
								E20	19.5	2	24.5	32.6	35
575-3-60	6.4	58.0	10.0	1.3	2.0	0.0	E30	28.8	2	36.1	46.6	50	
							None	-	-	-	11.0	15	
							E10	10.6	1	10.6	15.2	20	
							E15	15.9	1	16.0	21.6	25	
							E20	21.2	2	21.3	28.0	30	
							E30	30.4	2	30.5	39.1	40	

1. Minimum Circuit Ampacity.
2. Dual Element, Time Delay Type.
3. HACR type per NEC.

TABLE 22: ELECTRICAL DATA - DH036-060 BELT DRIVE HIGH STATIC W/O POWERED CONVENIENCE OUTLET

Size (Tons)	Volt	Compressors (each)			OD Fan Motors (each)	Supply Blower Motor	Pwr Conv Outlet	Electric Heat Option				MCA ¹ (Amps)	Max Fuse ² / Breaker ³ Size (Amps)
		RLA	LRA	MCC				Model	kW	Stages	Amps		
036 (3.0)	208-3-60	13.1	110.0	20.5	2.3	5.2	0.0	None	-	-	-	23.9	30
								E05	4.0	1	11.1	23.9	30
								E07	5.6	1	15.5	25.9	35
								E10	8.0	1	22.2	34.3	35
								E15	11.9	2	33.0	47.8	50
								E20	15.9	2	44.1	61.7	70
	230-3-60	13.1	110.0	20.5	2.3	5.2	0.0	None	-	-	-	23.9	30
								E05	5.3	1	13.3	23.9	30
								E07	7.5	1	18.8	29.1	35
								E10	10.6	1	26.6	38.4	40
								E15	15.9	2	39.9	54.3	60
								E20	21.2	2	53.2	70.2	80
	460-3-60	6.7	54.0	10.5	1.3	2.6	0.0	None	-	-	-	12.3	15
								E07	6.8	1	8.5	13.5	15
								E10	10.1	1	12.7	18.4	20
								E15	13.6	2	17.1	23.7	25
								E20	19.5	2	24.5	32.6	35
								E30	28.8	2	36.1	48.4	50
048 (4.0)	208-3-60	13.1	110.0	20.5	2.3	5.2	0.0	None	-	-	-	23.9	30
								E05	4.0	1	11.1	23.9	30
								E07	5.6	1	15.5	25.9	35
								E10	8.0	1	22.2	34.3	35
								E15	11.9	2	33.0	47.8	50
								E20	15.9	2	44.1	61.7	70
	230-3-60	13.1	110.0	20.5	2.3	5.2	0.0	None	-	-	-	23.9	30
								E05	5.3	1	13.3	23.9	30
								E07	7.5	1	18.8	29.1	35
								E10	10.6	1	26.6	38.4	40
								E15	15.9	2	39.9	54.3	60
								E20	21.2	2	53.2	70.2	80
	460-3-60	6.7	54.0	10.5	1.3	2.6	0.0	None	-	-	-	12.3	15
								E07	6.8	1	8.5	13.5	15
								E10	10.1	1	12.7	18.4	20
								E15	13.6	2	17.1	23.7	25
								E20	19.5	2	24.5	32.6	35
								E30	28.8	2	36.1	48.4	50
	575-3-60	5.1	44.0	8.0	1.3	2.0	0.0	None	-	-	-	9.4	15
								E10	10.6	1	10.6	15.2	20
								E15	15.9	1	16.0	21.6	25
								E20	21.2	2	21.3	28.0	30
060 (5.0)	208-3-60	16.0	137.0	25.0	2.3	8.2	0.0	None	-	-	-	30.5	40
								E05	4.0	1	11.1	30.5	40
								E07	5.6	1	15.5	30.5	40
								E10	8.0	1	22.2	38.0	45
								E15	11.9	2	33.0	51.5	60
								E20	15.9	2	44.1	65.4	70
								E30	22.2	2	61.6	87.3	90
	230-3-60	16.0	137.0	25.0	2.3	8.2	0.0	None	-	-	-	30.5	40
								E05	5.3	1	13.3	30.5	40
								E07	7.5	1	18.8	32.8	45
								E10	10.6	1	26.6	42.1	45
								E15	15.9	2	39.9	58.1	60
								E20	21.2	2	53.2	74.0	80
	460-3-60	8.3	69.0	13.0	1.3	4.1	0.0	None	-	-	-	15.8	20
								E07	6.8	1	8.5	15.8	20
								E10	10.1	1	12.7	20.3	25
								E15	13.6	2	17.1	25.6	30
								E20	19.5	2	24.5	34.4	35
								E30	28.8	2	36.1	48.4	50
	575-3-60	6.4	58.0	10.0	1.3	3.6	0.0	None	-	-	-	12.6	15
								E10	10.6	1	10.6	17.2	20
								E15	15.9	1	16.0	23.6	25
								E20	21.2	2	21.3	30.0	30
								E30	30.4	2	30.5	41.1	45

1. Minimum Circuit Ampacity.
2. Dual Element, Time Delay Type.
3. HACR type per NEC.

TABLE 23: ELECTRICAL DATA - DH036, 048 & 060 DIRECT DRIVE W/POWERED CONVENIENCE OUTLET

Size (Tons)	Volt	Compressors (each)			OD Fan Motors (each)	Supply Blower Motor	Pwr Conv Outlet	Electric Heat Option				MCA ¹ (Amps)	Max Fuse ² / Breaker ³ Size (Amps)
		RLA	LRA	MCC				Model	kW	Stages	Amps		
036 (3.0)	208-3-60	13.1	110.0	20.5	2.3	6.0	10.0	None	-	-	-	34.7	45
								E05	4.0	1	11.1	34.7	45
								E07	5.6	1	15.5	39.4	45
								E10	8.0	1	22.2	47.8	50
								E15	11.9	2	33.0	61.3	70
								E20	15.9	2	44.1	75.2	80
	230-3-60	13.1	110.0	20.5	2.3	6.0	10.0	None	-	-	-	34.7	45
								E05	5.3	1	13.3	35.9	45
								E07	7.5	1	18.8	42.6	45
								E10	10.6	1	26.6	51.9	60
								E15	15.9	2	39.9	67.8	70
								E20	21.2	2	53.2	83.7	90
048 (4.0)	208-3-60	13.1	110.0	20.5	2.3	7.6	10.0	None	-	-	-	36.3	45
								E05	4.0	1	11.1	36.3	45
								E07	5.6	1	15.5	41.4	45
								E10	8.0	1	22.2	49.8	50
								E15	11.9	2	33.0	63.3	70
								E20	15.9	2	44.1	77.2	80
	230-3-60	13.1	110.0	20.5	2.3	7.6	10.0	None	-	-	-	36.3	45
								E05	5.3	1	13.3	37.9	45
								E07	7.5	1	18.8	44.6	45
								E10	10.6	1	26.6	53.9	60
								E15	15.9	2	39.9	69.8	70
								E20	21.2	2	53.2	85.7	90
060 (5.0)	208-3-60	16.0	137.0	25.0	2.3	7.6	10.0	None	-	-	-	39.9	50
								E05	4.0	1	11.1	39.9	50
								E07	5.6	1	15.5	41.4	50
								E10	8.0	1	22.2	49.8	50
								E15	11.9	2	33.0	63.3	70
								E20	15.9	2	44.1	77.2	80
	230-3-60	16.0	137.0	25.0	2.3	7.6	10.0	E30	22.2	2	61.6	99.0	100
								None	-	-	-	39.9	50
								E05	5.3	1	13.3	39.9	50
								E07	7.5	1	18.8	44.6	50
								E10	10.6	1	26.6	53.9	60
								E15	15.9	2	39.9	69.8	70
								E20	21.2	2	53.2	85.7	90
								E30	29.6	2	74.3	111.0	125

1. Minimum Circuit Ampacity.
2. Dual Element, Time Delay Type.
3. HACR type per NEC.

TABLE 24: ELECTRICAL DATA - DH036-060 BELT DRIVE W/POWERED CONVENIENCE OUTLET

Size (Tons)	Volt	Compressors (each)			OD Fan Motors (each)	Supply Blower Motor	Pwr Conv Outlet	Electric Heat Option				MCA ¹ (Amps)	Max Fuse ² / Breaker ³ Size (Amps)
		RLA	LRA	MCC				Model	kW	Stages	Amps		
036 (3.0)	208-3-60	13.1	110.0	20.5	2.3	5.2	10.0	None	-	-	-	33.9	45
								E05	4.0	1	11.1	33.9	45
								E07	5.6	1	15.5	38.4	45
								E10	8.0	1	22.2	46.8	50
								E15	11.9	2	33.0	60.3	70
								E20	15.9	2	44.1	74.2	80
	230-3-60	13.1	110.0	20.5	2.3	5.2	10.0	None	-	-	-	33.9	45
								E05	5.3	1	13.3	34.9	45
								E07	7.5	1	18.8	41.6	45
								E10	10.6	1	26.6	50.9	60
								E15	15.9	2	39.9	66.8	70
								E20	21.2	2	53.2	82.7	90
	460-3-60	6.7	54.0	10.5	1.3	2.6	5.0	None	-	-	-	17.3	20
								E07	6.8	1	8.5	19.7	20
								E10	10.1	1	12.7	24.7	25
								E15	13.6	2	17.1	29.9	30
								E20	19.5	2	24.5	38.8	40
048 (4.0)	208-3-60	13.1	110.0	20.5	2.3	5.2	10.0	None	-	-	-	33.9	45
								E05	4.0	1	11.1	33.9	45
								E07	5.6	1	15.5	38.4	45
								E10	8.0	1	22.2	46.8	50
								E15	11.9	2	33.0	60.3	70
								E20	15.9	2	44.1	74.2	80
	230-3-60	13.1	110.0	20.5	2.3	5.2	10.0	None	-	-	-	33.9	45
								E05	5.3	1	13.3	34.9	45
								E07	7.5	1	18.8	41.6	45
								E10	10.6	1	26.6	50.9	60
								E15	15.9	2	39.9	66.8	70
								E20	21.2	2	53.2	82.7	90
	460-3-60	6.7	54.0	10.5	1.3	2.6	5.0	None	-	-	-	17.3	20
								E07	6.8	1	8.5	19.7	20
								E10	10.1	1	12.7	24.7	25
								E15	13.6	2	17.1	29.9	30
								E20	19.5	2	24.5	38.8	40
	575-3-60	5.1	44.0	8.0	1.3	2.0	4.0	None	-	-	-	13.4	15
								E10	10.6	1	10.6	20.2	25
								E15	15.9	1	16.0	26.6	30
								E20	21.2	2	21.3	33.0	35
060 (5.0)	208-3-60	16.0	137.0	25.0	2.3	5.2	10.0	None	-	-	-	37.5	50
								E05	4.0	1	11.1	37.5	50
								E07	5.6	1	15.5	38.4	50
								E10	8.0	1	22.2	46.8	50
								E15	11.9	2	33.0	60.3	70
								E20	15.9	2	44.1	74.2	80
	230-3-60	16.0	137.0	25.0	2.3	5.2	10.0	None	-	-	-	37.5	50
								E05	5.3	1	13.3	37.5	50
								E07	7.5	1	18.8	41.6	50
								E10	10.6	1	26.6	50.9	60
								E15	15.9	2	39.9	66.8	70
								E20	21.2	2	53.2	82.7	90
	460-3-60	8.3	69.0	13.0	1.3	2.6	5.0	None	-	-	-	19.3	25
								E07	6.8	1	8.5	19.7	25
								E10	10.1	1	12.7	24.7	25
								E15	13.6	2	17.1	29.9	30
								E20	19.5	2	24.5	38.8	40
								E30	28.8	2	36.1	52.8	60
	575-3-60	6.4	58.0	10.0	1.3	2.0	4.0	None	-	-	-	15.0	20
								E10	10.6	1	10.6	20.2	25
								E15	15.9	1	16.0	26.6	30
								E20	21.2	2	21.3	33.0	35
								E30	30.4	2	30.5	44.1	45

1. Minimum Circuit Ampacity.
2. Dual Element, Time Delay Type.
3. HACR type per NEC.

TABLE 25: ELECTRICAL DATA - DH036-060 BELT DRIVE HIGH STATIC W/POWERED CONVENIENCE OUTLET

Size (Tons)	Volt	Compressors (each)			OD Fan Motors (each)	Supply Blower Motor	Pwr Conv Outlet	Electric Heat Option				MCA ¹ (Amps)	Max Fuse ² / Breaker ³ Size (Amps)
		RLA	LRA	MCC				Model	kW	Stages	Amps		
036 (3.0)	208-3-60	13.1	110.0	20.5	2.3	5.2	10.0	None	-	-	-	33.9	45
								E05	4.0	1	11.1	33.9	45
								E07	5.6	1	15.5	38.4	45
								E10	8.0	1	22.2	46.8	50
								E15	11.9	2	33.0	60.3	70
								E20	15.9	2	44.1	74.2	80
	230-3-60	13.1	110.0	20.5	2.3	5.2	10.0	None	-	-	-	33.9	45
								E05	5.3	1	13.3	34.9	45
								E07	7.5	1	18.8	41.6	45
								E10	10.6	1	26.6	50.9	60
								E15	15.9	2	39.9	66.8	70
								E20	21.2	2	53.2	82.7	90
	460-3-60	6.7	54.0	10.5	1.3	2.6	5.0	None	-	-	-	17.3	20
								E07	6.8	1	8.5	19.7	20
								E10	10.1	1	12.7	24.7	25
								E15	13.6	2	17.1	29.9	30
								E20	19.5	2	24.5	38.8	40
048 (4.0)	208-3-60	13.1	110.0	20.5	2.3	5.2	10.0	None	-	-	-	33.9	45
								E05	4.0	1	11.1	33.9	45
								E07	5.6	1	15.5	38.4	45
								E10	8.0	1	22.2	46.8	50
								E15	11.9	2	33.0	60.3	70
								E20	15.9	2	44.1	74.2	80
	230-3-60	13.1	110.0	20.5	2.3	5.2	10.0	None	-	-	-	33.9	45
								E05	5.3	1	13.3	34.9	45
								E07	7.5	1	18.8	41.6	45
								E10	10.6	1	26.6	50.9	60
								E15	15.9	2	39.9	66.8	70
								E20	21.2	2	53.2	82.7	90
	460-3-60	6.7	54.0	10.5	1.3	2.6	5.0	None	-	-	-	17.3	20
								E07	6.8	1	8.5	19.7	20
								E10	10.1	1	12.7	24.7	25
								E15	13.6	2	17.1	29.9	30
								E20	19.5	2	24.5	38.8	40
	575-3-60	5.1	44.0	8.0	1.3	2.0	4.0	None	-	-	-	13.4	15
								E10	10.6	1	10.6	20.2	25
								E15	15.9	1	16.0	26.6	30
								E20	21.2	2	21.3	33.0	35
060 (5.0)	208-3-60	16.0	137.0	25.0	2.3	8.2	10.0	None	-	-	-	40.5	50
								E05	4.0	1	11.1	40.5	50
								E07	5.6	1	15.5	42.2	50
								E10	8.0	1	22.2	50.5	60
								E15	11.9	2	33.0	64.0	70
								E20	15.9	2	44.1	77.9	80
	230-3-60	16.0	137.0	25.0	2.3	8.2	10.0	E30	22.2	2	61.6	99.8	100
								None	-	-	-	40.5	50
								E05	5.3	1	13.3	40.5	50
								E07	7.5	1	18.8	45.3	50
								E10	10.6	1	26.6	54.6	60
								E15	15.9	2	39.9	70.6	80
	460-3-60	8.3	69.0	13.0	1.3	4.1	5.0	E20	21.2	2	53.2	86.5	90
								E30	29.6	2	74.3	111.8	125
								None	-	-	-	20.8	25
								E07	6.8	1	8.5	21.6	25
								E10	10.1	1	12.7	26.6	30
								E15	13.6	2	17.1	31.8	35
	575-3-60	6.4	58.0	10.0	1.3	3.6	4.0	E20	19.5	2	24.5	40.7	45
								E30	28.8	2	36.1	54.7	60
								None	-	-	-	16.6	20
								E10	10.6	1	10.6	22.2	25
								E15	15.9	1	16.0	28.6	30
								E20	21.2	2	21.3	35.0	35
								E30	30.4	2	30.5	46.1	50

1. Minimum Circuit Ampacity.
2. Dual Element, Time Delay Type.
3. HACR type per NEC.

TABLE 26: PHYSICAL DATA

MODELS		DH		
		036	048	060
EVAPORATOR BLOWER	Centrifugal Blower (Dia. x Wd. in.)	12 X 10	12 X 10	12 X 10
	Fan Motor HP (Direct Drive)	3/4	1	1
	Fan Motor HP (Belt Drive)	1 1/2	1 1/2	1 1/2
	Fan Motor HP (Belt Drive High Static)	1 1/2	1 1/2	2
EVAPORATOR COIL	Rows Deep	4	4	4
	Fins Per Inch	13	13	13
	Face Area (Sq. Ft.)	4.3	5.1	5.1
CONDENSER FANS	Propeller Dia. (in.)	24	24	24
	Fan Motor Hp	1/2	1/2	1/2
	Nom. CFM	4500	4200	4200
CONDENSER COILS	Rows Deep	2	2	2
	Fins Per Inch	18	18	18
	Face Area (Sq. Ft.)	17.1	17.1	17.1
COMPRESSOR (Qty. Per Unit)	Recip. Type	1	1	1
AIR FILTERS	Quantity Per Unit (15" X 20" X 1" or 2")	2	2	2
	Quantity Per Unit (14" X 25" X 1" or 2")	1	1	1
	Total Face Area (sq. ft.)	6.3	6.3	6.3
CHARGE	Refrigerant 22 (lbs./oz.)	10/8	10/4	10/14

TABLE 27: ELECTRIC HEAT CORRECTION FACTORS


NOMINAL VOLTAGE	VOLTAGE	kW CAP. MULTIPLIER
208	208	0.75
240	230	0.92
480	460	0.92
600	575	0.92

TABLE 28: VOLTAGE LIMITATIONS¹

POWER SUPPLY	VOLTAGE	
	MIN.	MAX.
208/230-3-60	187	253
460-3-60	414	506
575-3-60	540	630


1. Utilization Range "A" in accordance with ARI Standard 110.

TYPICAL POWER WIRING




TYPICAL CONTROL WIRING

COOLING ONLY (24 VOLT THERMOSTAT)




¹24 VOLT THERMOSTAT 2TH07701024. TO CONTROL THE ECONOMIZER ON SECOND STAGE COOLING, USE THE THERMOSTAT 2TH0401224.

COOLING / HEATING (24 VOLT THERMOSTAT)



COOLING / HEATING (ELECTRONIC THERMOSTAT) MULTI STAGE



¹ ELECTRONIC PROGRAMMABLE THERMOSTAT 2ET04700224 (INCLUDES SUBBASE).


² SECOND STAGE COOLING IS NOT REQUIRED ON UNITS LESS ECONOMIZER.

³ SECOND STAGE HEATING IS ONLY REQUIRED ON UNITS WITH A TWO STAGE ELECTRIC HEATER OR 2 STAGE GAS HEAT.

⁴ REMOVE JUMPER J2 FROM TERMINALS 4 AND 9 ON JUMPER PLUG CONNECTOR P6 ON UNITS WITH ECONOMIZER. TERMINALS A1 AND A2 PROVIDE A RELAY OUT-PUT TO CLOSE THE OUTDOOR ECONOMIZER DAMPERS WHEN THE THERMOSTAT SWITCHES TO THE SET-BACK POSITION.

¹24 VOLT THERMOSTAT 2ET07701024. TO CONTROL THE ECONOMIZER ON THE SECOND STAGE COOLING OR TO HAVE AN ELECTRIC HEAT ACCESSORY WITH TWO STAGES OF HEAT, USE THERMOSTAT 2TH0471024.

COOLING / HEATING (ELECTRONIC THERMOSTAT) SINGLE STAGE



¹ELECTRONIC PROGRAMMABLE THERMOSTAT 2ET07701024 (INCLUDES SUBBASE). TO CONTROL THE ECONOMIZER ON SECOND STAGE COOLING, USE THERMOSTAT 2TH04700224.

FIGURE 2 - TYPICAL FIELD POWER & CONTROL WIRING




FIGURE 3 - UNIT DIMENSIONS (3 - 5 TON COOLING ONLY/ELECTRIC HEAT) FRONT VIEW




FIGURE 4 - UNIT DIMENSIONS (3 - 5 TON COOLING/GAS HEAT) FRONT VIEW




FIGURE 5 - UNIT WITH ECONOMIZER RAINHOOD





FIGURE 6 - UNIT WITH FIXED OUTDOOR AIR/MOTORIZED DAMPER RAINHOOD



DUCT COVERS - Units are shipped with all air duct openings covered.

For side duct applications;

1. Remove and discard the supply and return air duct covers.
2. Connect ductwork to duct flanges on the rear of the unit.

For bottom duct applications;

1. Remove the side supply air duct cover to gain access to the bottom supply air knockout panel.
2. Remove and discard the bottom knockout panel.
3. Replace the side duct cover.
4. With filter section access panel removed from the unit, remove and discard the bottom return air knockout panel.
5. Replace the filter access panel.

FIGURE 7 - UNIT DIMENSIONS (REAR VIEW)




FIGURE 8 - DISCONNECT/BLOWER ACCESS LOCATION

TABLE 30: MINIMUM CLEARANCES

LOCATION	CLEARANCE
Front	24" (Cooling/Electric Heat)
	32" (Gas Heat)
Rear	12" (Less Economizer)
	36" (With Economizer or Fixed Air/Motorized Damper)
Left Side (Filter Access)	24" (Less Economizer)
Right Side (Cond. Coil)	36" (With Economizer)
Below Unit ¹	0"
Above Unit ²	72" (For Condenser Air Discharge)

1. Units may be installed on combustible floors made from wood or class A, B, or C roof covering material.
2. Units must be installed outdoors. Overhanging structures or shrubs should not obstruct condenser air discharge outlet.

TABLE 29: UTILITIES ENTRY

HOLE	OPENING SIZE (DIA.)	USED FOR	
A	7/8" KO ¹	Control Wiring ²	Side
			Bottom
B	2" KO ¹	Power Wiring	Side
			Bottom
C	1-5/8" KO	Gas Piping (Front)	
D	1-1/2" KO	Gas Piping (Bottom)	

1. Opening in the bottom to the unit can be located by the side in the insulation.
2. Do not remove the 2" knockout ring.





FIGURE 9 - TYPICAL APPLICATIONS




FIGURE 10 - FOUR AND SIX POINT LOADING

TABLE 31: DH 4 AND 6 POINT LOADS WEIGHT DISTRIBUTION


UNIT	TOTAL	4-Point Loading (lb)				6-Point Loading (lb)					
		A	B	C	D	A	B	C	D	E	F
DH036 Cooling/ Electric	565	125	123	157	160	84	83	82	104	105	107
DH036N04	605	134	132	168	171	90	89	88	112	113	114
DH036D06	615	137	134	171	174	91	90	89	113	115	116
DH036N08	625	139	136	173	177	93	92	91	115	117	118
DH036D10	635	141	138	176	179	94	93	92	117	119	120
DH048 Cooling/ Electric	610	135	133	169	172	91	89	88	112	114	115
DH048(D,N)06	660	147	144	183	186	98	97	96	122	123	125
DH048(D,N)10	680	151	148	189	192	101	100	99	125	127	128
DH060 Cooling/ Electric	645	143	141	179	182	96	95	93	119	120	122
DH060D06	695	154	152	193	196	103	102	101	128	130	131
DH060N08	705	157	154	196	199	105	103	102	130	132	133
DH060(D,N)10	715	159	156	198	202	106	105	104	132	133	135

TABLE 32: CENTER OF GRAVITY

DIMENSION	3 - 5 TON
X	40-3/4"
Y	19-3/4"

TABLE 33: OPERATING WEIGHTS (LBS.)

MODEL SIZE			3 TON	4 TON	5 TON
BASIC UNIT	DH (Cooling Only)		565	610	645
	DH (Gas/Electric)	N04	605	-	-
		N06	-	660	-
		N08	625	-	705
		N10	-	680	715
		D06	615	660	695
		D10	635	680	715
OPTIONS	Economizer		50 26 18 23 28 92 10 5		
	Motorized Damper				
	Electric Heater	5 - 7 kW			
		10 - 15 kW			
		20 - 30 kW			
ACCY.	Roof Curb				
	Barometric Relief / Fixed Air Damper				
	Belt-Drive Blower				

**FIGURE 11 - ROOF CURB DIMENSIONS**

GUIDE SPECIFICATIONS

GENERAL

Units shall be manufactured by York International Unitary Products Group in an ISO 9001 certified facility.

York's Sunline Ultra® units are convertible single package units. Although the units are primarily designed for curb mounting on a roof, they can also be slab-mounted at ground level or set on steel beams above a finished roof. Cooling only, cooling with gas heat and cooling with electric heat models are available with a wide variety of factory-mounted options and field-installed accessories to make them suitable for almost every application. All units are self-contained and assembled on full perimeter base rails with holes in the four corners for overhead rigging. Every unit is completely piped, wired, charged and tested at the factory to simplify the field installation and to provide years of dependable operation. All models (including those with an economizer) are suitable for either bottom or horizontal duct connections. Models with power exhaust are suitable for bottom duct connections only. For bottom duct, remove the sheet metal panels from the supply and return air openings through the base of the unit. For horizontal duct, remove the supply and return air panels on the rear of the unit.

All non-Scroll compressors include crankcase heaters and all compressors have internal pressure relief. Every refrigerant circuit includes a liquid line filter-drier, a discharge line high pressure switch and a suction line with a freeze-stat and low pressure/loss of charge switch. The unit control circuit includes a 75 VA transformer, a 24-volt circuit breaker and a relay board with a compressor lockout circuit, a terminal strip for thermostat wiring, plus an additional set of pin connectors to simplify the interface of additional field controls. All units have long lasting powder paint cabinets with 750 hour salt spray test approval under ASTM B117 procedures. All models are CSA listed. All models include a 1-year limited warranty on the complete unit. Compressors and electric heater elements carry a 5-year warranty. Aluminumized steel and Stainless steel tubular heat exchangers carry a 10-year warranty.

DESCRIPTION

Units shall be factory-assembled, single packaged, Electric Cooling/Gas Heat, Electric Cooling/Optional Electric Heat and designed for outdoor mounted installation.

The 3 ton, 4 ton and 5 ton units shall have minimum SEER ratings of 12.2, 13.2 and 12.2 respectively. They shall have built-in field convertible duct connections for down discharge supply/return or horizontal discharge supply/return, and be available with factory installed options or field installed accessories. The units shall be factory wired, piped, charged with R-22 refrigerant and factory tested prior to shipment. All unit wiring shall be both numbered and color coded. All units the cooling performance shall be rated in accordance with DOE and ARI test procedures. Units shall be CSA listed, classified to ANSI Z21.47, UL 1995/CSA No. 236 standards.

UNIT CABINET

Unit cabinet shall be constructed of a combination of G60 and G90 galvanized steel, with exterior surfaces coated with a non-chalking, powdered paint finish, certified at 750 hours salt spray test per ASTM B117 standards. Indoor blower section shall be insulated with a minimum 1/2" thick insulation, coated on the airside. Aluminum foil faced insulation shall be used in the furnace compartment and be fastened with ridged fasteners to prevent insulation from entering the air stream. Cabinet panels shall be "large" size, easily removable for servicing and maintenance. Full perimeter base rails shall be provided to assure reliable transit of equipment, overhead rigging and proper sealing on roof curb applications. Disposable 1" filters shall be furnished and be accessible through a removable access door, sealed airtight. Units filter track shall be designed to accommodate either 1" or 2" filters. Fan performance measuring ports shall be provided on the outside of the cabinet to allow accurate air measurements of evaporator fan performance without removing panels or creating air bypass of the coils. Condensate pan shall be internally sloped and conform to ASHRAE 62-89 self-draining standards. Condensate connection shall be a minimum of 3/4" I.D. female and be a ridged mount connection.

INDOOR (EVAPORATOR) FAN ASSEMBLY

The indoor fan shall be a factory installed with either direct drive or belt drive assembly that includes an adjustable pitch motor pulley. Job site selected brake horsepower (B.H.P.) shall not exceed the motors nameplate horsepower rating, plus the service factor. Units shall be designed not to operate above service factor. Fan wheel shall be double-inlet type with forward-curved blades, dynamically balanced to operate smoothly throughout the entire range of operation. Airflow design shall be constant air volume. Bearings shall be sealed and permanently lubricated for longer life and no maintenance.

OUTDOOR (CONDENSER) FAN ASSEMBLY

The outdoor fan shall be of the direct-driven propeller type, discharge air vertically, have aluminum blades riveted to a corrosion resistant steel spider bracket and shall be dynamically balanced for smooth operation. The outdoor fan motor shall be totally enclosed with permanently lubricated bearings, internally protected against overload conditions and staged independently.

REFRIGERANT COMPONENTS

Compressor:

- a. Shall be internally protected with internal high-pressure relief and over temperature protection.
- b. Shall have internal spring isolation and sound muffling to minimize vibration and noise, and be externally isolated on a dedicated, independent mounting.

Coils:

- a. Evaporator and condenser coils shall have aluminum plate fins mechanically bonded to seamless internally enhanced copper tubes with all joints brazed. Special Phenolic coating shall be available as a factory option.
- b. Evaporator and Condenser coils shall be of the direct expansion, draw-thru, design.

Refrigerant Circuit and Refrigerant Safety Components shall include:

- a. Thermal expansion devices (TXV's).
- b. Filter drier/strainer to eliminate any moisture or foreign matter.
- c. Accessible service gage connections on both suction and liquid lines to charge, evacuate, and measure refrigerant pressure during any necessary servicing or troubleshooting, without losing charge.
- d. The refrigeration system shall provide at least 15°F of sub-cooling at design conditions.

UNIT CONTROLS

- a. Unit shall be complete with self-contained low-voltage control circuit protected by a resettable circuit breaker on the 24-volt transformer side.
- b. Unit shall incorporate a lockout circuit which provides reset capability at the space thermostat or base unit, should any of the following standard safety devices trip and shut off compressor.
- c. Loss-of-charge/Low-pressure switch.
- d. High-pressure switch.
- e. Freeze-protection thermostat, evaporator coil.
- f. If any of the above safety devices trip, a LED (light-emitting diode) indicator shall flash a diagnostic code that indicates which safety switch has tripped.
- g. Unit shall incorporate "AUTO RESET" compressor over temperature, over current protection.
- h. Unit shall operate with conventional thermostat designs and have a low voltage terminal strip for easy hook-up.
- i. Unit control board shall have on-board diagnostics and fault code display.
- j. Standard controls shall include anti-short cycle and low voltage protection, and permit cooling operation down to 0°F.
- k. Control board shall monitor each refrigerant safety switch independently.
- l. Control board shall retain last 5 fault codes in non volatile memory which will not be lost in the event of a power loss.

GAS HEATING SECTION (SINGLE OR 2 STAGE)

Shall be designed with induced draft combustion with post purge logic, energy saving direct spark ignition, and redundant main gas valve. Venter wheel shall be constructed of stainless steel for corrosion resistance. The heat exchanger shall be of the tubular type, constructed of T1-40 aluminized steel for corrosion resistance and allowing minimum mixed air entering temperature of 25°F. Burners shall be of the inshot type, constructed of aluminum coated steel and contain air mixture adjustments. All gas piping shall enter the unit cabinet at a single location through either the side or curb without any field modifications. Integrated control boards shall provide timed control of evaporator fan functioning and burner ignition. Heating section shall be provided with the following minimum protection:

- a. Primary and auxiliary high-temperature limit switches.
- b. Induced draft motor speed sensor.
- c. Flame roll out switch.
- d. Flame proving controls.
- e. If any of the above safety devices trip, a LED (light-emitting diode) indicator shall flash a diagnostic code that indicates which safety switch has tripped.

ELECTRIC HEATING SECTION

An electric heating section, with nickel chromium elements, shall be provided in a range of 5 thru 30 KW, offering two stages of capacity - 16 KW and above on 208/230 volt heaters and 20 KW and above on 460 and 575 volt heaters. The heating section shall have a primary limit control(s) and automatic reset to prevent the heating element system from operating at an excessive temperature. The heating section assembly shall slide out of the unit for easy maintenance and service. Units with Electric Heating shall be wired for a single point power supply with branch circuit fusing (where required).

UNIT OPERATING CHARACTERISTICS

- a. Unit shall be capable of starting and running at 125°F outdoor temperature, exceeding maximum load criteria of ARI Standard 210/240. The compressor, with standard controls, shall be capable of operation down to 0°F outdoor temperature. Unit shall be provided with fan time delay to prevent cold air delivery before heat exchanger warms up (Gas heat only).

ELECTRICAL REQUIREMENTS

All unit power wiring shall enter unit cabinet at a single factory provided location and be capable of side or bottom entry, to minimize roof penetrations and avoid unit field modifications. Separate side and bottom openings shall be provided for the control wiring.

STANDARD LIMITED WARRANTIES

- Compressor 5 Years
- Heat Exchanger 10 Years
- Electric Heat Element 5 Years
- Other Parts 1 Year

OPTIONAL OUTDOOR AIR (Shall be made available by either/or):

- **ELECTRONIC ENTHALPY AUTOMATIC ECONOMIZER**- Outdoor and return air dampers that are interlocked and positioned by a fully-modulating, spring return damper actuator. The maximum leakage rate for the outdoor air intake dampers shall not exceed 2% when dampers are fully closed and operating against a pressure differential of 0.5 IWG. A unit-mounted potentiometer shall be provided to adjust the outdoor and return air damper assembly to take in CFM of outdoor air to meet the minimum ventilation requirement of the conditioned space during normal operation. During economizer operation, a mixed-air temperature control shall modulate the outdoor and return air damper assembly to prevent the supply air temperature from dropping below 55°F. Changeover from compressor to economizer operation shall be provided by an integral electronic enthalpy control that feeds input into the basic module. The outdoor intake opening shall be covered with a rain hood that matches the exterior of the unit. Water eliminator/filters shall be provided. Simultaneous economizer/compressor operation is also possible. Dampers shall fully close on power loss.
- **MOTORIZED OUTDOOR AIR DAMPERS** - Outdoor air dampers are positioned by a 2-position, spring-return damper actuator. The maximum leakage rate for the outdoor air intake dampers shall not exceed 2% when dampers are fully closed and operating against a pressure differential of 0.5 IWG. A unit-mounted potentiometer shall be provided to adjust the outdoor damper assembly to take in the design CFM of outdoor air to meet the ventilation requirements of the conditioned space during normal operation. Whenever the indoor fan motor is energized, the dampers open up to one of two pre-selected positions - regardless of the outdoor air enthalpy. Dampers return to the fully closed position when the indoor fan motor is de-energized. Dampers shall fully close on power loss.

OTHER PRE-ENGINEERED ACCESSORIES AVAILABLE

- **ROOF CURB** - 14"and 8" high, full perimeter curb with wood nailer (shipped knocked-down).
- **BAROMETRIC RELIEF DAMPER** - Contains a rain hood, air inlet screen, exhaust damper and mounting hardware. Used to relieve internal air pressure through the unit.
- **PROPANE CONVERSION KIT** - Contains new orifices and gas valve parts to convert from natural to L.P. gas. One per unit required.
- **HIGH ALTITUDE - NATURAL GAS** - Contains orifices required for applications between 2000 and 6000 feet altitude.
- **HIGH ALTITUDE - PROPANE GAS** - Contains orifices required for applications between 2000 and 6000 feet altitude. Must be used with propane conversion kit.
- **LOW NOX** - Required to reduce the emission of nitrogen oxides below 40 nanograms per joule.
- **GAS PIPING** - Contains 1/2" pipe nipples, fittings and gas cock (including panel assess gaskets) required for bottom gas supply connection with external shut off.
- **POWER EXHAUST OPTION** - To work in conjunction with economizers.
- **ELECTRIC HEATERS**
- **ECONOMIZER/MOTORIZED DAMPER RAIN HOOD** - Contains all hood panels and the hardware for assembling.
- **MANUAL OUTDOOR AIR DAMPER**
- **COIL GUARD KIT** - Guard for cooling coil.
- **HAIL GUARD**
- **FLUE EXHAUST EXTENSION**

OTHER FACTORY INSTALLED OPTIONS

- **POWER EXHAUST OPTION** - To work in conjunction with economizers.
- **STAINLESS STEEL HEAT EXCHANGER**
- **STAINLESS STEEL DRAIN PAN**
- **BOTTOM DRAIN CONNECTION**

- **TECHNICOAT PHENOLIC COATED CONDENSER AND EVAPORATOR COIL**
- **ELECTRONIC SINGLE ENTHALPY ECONOMIZER**
- **DIRTY FILTER SWITCH**
- **PHASE MONITOR**
- **COIL GUARD**
- **POWERED GFI CONVENIENCE OUTLET**
- **NON-POWERED GFI CONVENIENCE OUTLET**
- **BAS CONTROLS (Simplicity® INTELLI-Comfort™, CPC, JOHNSON, HONEYWELL, NOVAR)**
- **BAS READY ECONOMIZER (2-10 V.D.C. ACTUATOR WITHOUT A CONTROLLER)**
- **HINGED FILTER DOOR ACCESS AND TOOLESS ACCESS PANELS**
- **2" PLEATED FILTERS**
- **DISCONNECT SWITCH**
- **SUPPLY AIR SMOKE DETECTOR**
- **RETURN AIR SMOKE DETECTOR**
- **HIGH STATIC DRIVE OPTION** - May include a belt, blower pulley, motor pulley or a motor change to enhance blower performance.

Subject to change without notice. Printed in U.S.A.
Copyright © 2008 by Johnson Controls, Inc. All rights reserved.

254597-YTG-C-0308
Supersedes: 254597-YTG-B-0507

Johnson Controls Unitary Products
5005 York Drive
Norman, OK 73069