



Ducted Systems Technical Services Service Tips Letter

Letter: **STR-007-24**

Date: September 27, 2024

To: All Ducted Systems Branch Service, Sales, and Training Managers
All Ducted Systems Distribution Service, Sales, and Training Managers

Subject: Certification of 1CK0604 with new non-condensing furnace models

Product: Y81E, Z8ES, Y82E, Z8ET, Y82V, Z8VT, RL18


Effective: **September 25, 2024**

Masonry chimney draft hood kit 1CK0604 is a required accessory to vent an 80% induced draft furnace into a properly sized masonry lined chimney that does not have a metal liner in it. The draft hood kit installs on top of the gas furnace over the outlet of the draft inducer. It contains a limit switch that wires in series with the high limit switch on the gas furnace. The kit is available through Source 1 as part number S1-1CK0604.

The purpose of this letter is to provide **certification** that 1CK0604 is an approved accessory for use with non-condensing furnace models Y81E, Z8ES, Y82E, Z8ET, Y82V, Z8VT, and RL18.

The installation instructions included in kit 1CK0604 are in the process of being updated to reflect these new furnace model numbers, however we realize there are kits in the distribution channel that contain installation instructions that do not reflect these new furnace models.

If you have any questions on this, feel free to call Ducted Systems Technical Services at 1-877-UPG-SERV and speak with a technical support representative or contact your Regional Technical Service Manager.



A handwritten signature in black ink, appearing to read 'Casey McConaughy'.

Casey McConaughy
UPG Regional Technical Service Manager
Ducted Systems Technical Services - Johnson Controls

A handwritten signature in black ink, appearing to read 'Tom Tasker'.

Tom Tasker
Product Manager, Residential Furnaces
Ducted Systems - Johnson Controls